



West Virginia Parkways Authority

ADDENDUM #1

Date: 6/4/19

RFP: Prefab Modular Building BCS-1-19

Bid Opening Date: June 11th, 2019 @ 2PM

Addition to Pages 6-7 1.2 SCOPE OF WORK of RFP:

Insert Q. To meet code requirements, all restrooms are to have ceiling mounted ventilation fans that are vented to the outside by means of roof or soffit.

Sign and submit Addendum with your bid pkg.

Signature _____