



West Virginia Department of Transportation

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 07 **Plant Name:** ACX1.01.601 Central Supply F-8 @ Buckhannon
Last Inspection: 09/10/2019 **Sticker Expires:** 3/10/2020 **Standard Deviation:** 665.88 **Rating:** A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434200	601.002.003 Concrete, Class B		2.87	2.63	16	3000	1.543	3.233	471.37	6043.75	> 4523.94	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
1434200	601.002.003 Concrete, Class B		2.87	2.87	32	3000	1.5	3	816.14	4224.21	< 4634.69	< 5448.42
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
1434200	601.002.003 Concrete, Class B		2.87	2.63	22	3000	1.518	3.096	555.49	4908.18	> 4719.8	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last Three Months of Data Slump Less than 2 inches												
1434200	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1434200	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
1434211	601.002.001 Concrete, Class A		3.47	3.47	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Two Years of Data Slump Greater than or equal to 2 inches												
1434211	601.002.001 Concrete, Class A		3.47	3.47	12	3500	1.576	3.429	1183.31	5364.9	< 6178.5	< 7557.57
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
1434213	601.002.003 Concrete, Class B		2.87	2.87	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Two Years of Data Slump Greater than or equal to 2 inches												
1434213	601.002.003 Concrete, Class B		2.87	2.87	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1434213	601.002.003 Concrete, Class B		2.87	2.63	26	3000	1.508	3.044	585.97	5551.54	> 4783.69	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434217	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1434225	601.002.004 Concrete, Class B Modified		3.35	3.35	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1434229	601.002.016 Concrete, Class K Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1434233	601.002.011 Concrete, Class D		2.04	2.04	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1436388	601.002.015 Concrete, Class K		3.35	3.35	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1436444	601.002.013 Concrete, Class H		3.45	3.45	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1455043	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1459838	601.002.003 Concrete, Class B		2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1459842	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461801	679.002.002 Concrete, Microsilica		3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463308	601.002.001 Concrete, Class A	03/09/2019	3.49	3.49	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463317	601.002.015 Concrete, Class K	03/09/2019	3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463322	601.002.003 Concrete, Class B	03/09/2019	2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901027	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901397	601.002.011 Concrete, Class D		2.03	2.03	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901401	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 02

Plant Name: ATA1.01.601 Adams Trucking And Supply @ Barboursville, W

Last Inspection: 08/27/2019

Sticker Expires: 2/27/2020

Standard Deviation: 587.78

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1424602	601.002.003		2.87	2.87	36	3000	1.5	3	685.66	4028.49	< 4259.44	< 5056.98
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1424602	601.002.003		2.87	2.87	36	3000	1.5	3	685.66	4028.49	< 4259.44	< 5056.98
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Greater than or equal to 2 inches												
1424602	601.002.003		2.87	2.87	14	3000	1.557	3.313	669.46	4042.35	< 4906.43	< 5217.92
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1424606	601.002.013		3.35	3.35	3							
	Concrete, Class H				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
1424606	601.002.013		3.35	3.35	8							
	Concrete, Class H				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1424607	601.002.015	03/20/2019	3.36	3.36	2							
	Concrete, Class K				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Three Months of Data Slump Less than 2 inches

1465018	601.002.015 Concrete, Class K		3.35	3.35	5							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Greater than or equal to 2 inches

1465018	601.002.015 Concrete, Class K		3.35	3.35	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Three Months of Data Slump Greater than or equal to 2 inches

1465064	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1465065	601.002.003 Concrete, Class B		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 09 Plant Name: BMC1.01.601 Central Supply F-9 @ Summersville, WV
 Last Inspection: 06/03/2019 Sticker Expires: 12/3/2019 Standard Deviation: 863.25 Rating: A-2

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1432574	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last One Year of Data Slump Greater than or equal to 2 inches												
1432590	601.002.003 Concrete, Class B		2.87	2.87	33	3000	1.5	3	976.77	4465.16	< 5019.39	< 5930.31
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

Last Three Months of Data Slump Greater than or equal to 2 inches												
1432590	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434175	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434222	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436461	601.002.023 Concrete, Class H-IC	02/11/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436465	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459809	601.002.001 Concrete, Class A		3.60	3.60	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461848	601.002.022 Concrete, Class DC		3.59	3.59	8							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463336	601.002.003 Concrete, Class B		2.87	2.87	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901015	601.002.022 Concrete, Class DC		3.59	3.59	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901018	601.002.003 Concrete, Class B		2.87	2.87	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901021	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901024	601.002.001 Concrete, Class A		3.63	3.63	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 10

Plant Name: BMC1.02.601 Central Supply F-10 @ Wolfpen, WV

Last Inspection: 11/14/2018

Sticker Expires: 5/14/2019

Standard Deviation: 650.00

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1432577	601.002.003 Concrete, Class B		2.87	2.87	2							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last One Year of Data Slump Less than 2 inches

1434170	601.002.015 Concrete, Class K	10/24/2019	3.35	3.35	2							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

Last One Year of Data Slump Greater than or equal to 2 inches

1434170	601.002.015 Concrete, Class K	10/24/2019	3.35	3.35	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1436468	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1436469	601.002.013 Concrete, Class H		3.45	3.45	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1455007	601.002.022 Concrete, Class DC		3.61	3.61	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1463203	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1463303	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465014	601.002.013 Concrete, Class H		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901004	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901007	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901013	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 10

Plant Name: BMC1.03.601 Central Supply F-11 @ Princeton, WV

Last Inspection: 05/15/2019

Sticker Expires: 11/15/2019

Standard Deviation: 653.60

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1432575	601.002.003 Concrete, Class B		2.87	2.63	48	3000	1.5	3	573.13	5205.21	> 4719.39	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last One Year of Data Slump Less than 2 inches												
1432575	601.002.003 Concrete, Class B		2.87	2.87	6							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1432575	601.002.003 Concrete, Class B		2.87	2.63	72	3000	1.5	3	687.1	5407.29	> 5061.3	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1432575	601.002.003 Concrete, Class B		2.87	2.87	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434168	601.002.015 Concrete, Class K	10/23/2019	3.35	3.35	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last One Year of Data Slump Greater than or equal to 2 inches

1434181	601.002.003 Concrete, Class B		2.87	2.87	18	3000	1.533	3.175	718.43	4101.35 <	4320.56 <	5281.02
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

Last One Year of Data Slump Greater than or equal to 2 inches

1434181	601.002.003 Concrete, Class B		2.87	2.87	18	3000	1.533	3.175	718.43	4101.35 <	4320.56 <	5281.02
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Three Months of Data Slump Greater than or equal to 2 inches

1436467	601.002.013 Concrete, Class H		3.45	3.45	3							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1455001	601.002.013 Concrete, Class H	05/13/2018	3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1455005	601.002.022 Concrete, Class DC		3.61	3.61	2							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last One Year of Data Slump Greater than or equal to 2 inches

1463301	601.002.003 Concrete, Class B		2.87	2.87	3							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

Last Three Months of Data Slump Greater than or equal to 2 inches

1463301	601.002.003 Concrete, Class B		2.87	2.87	8							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1463344	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1901003	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1901006	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901009	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901010	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901012	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 10

Plant Name: BMC1.04.601 Central Supply F-12 @ Bluefield, WV

Last Inspection: 05/15/2019

Sticker Expires: 11/15/2019

Standard Deviation: 232.27

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last One Year of Data Slump Greater than or equal to 2 inches

1432576	601.002.003 Concrete, Class B		2.87	2.87	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1434169	601.002.015 Concrete, Class K	10/23/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1434182	601.002.003 Concrete, Class B		2.87	2.87	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last One Year of Data Slump Less than 2 inches

1434182	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last One Year of Data Slump Greater than or equal to 2 inches

1434182	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436487	601.002.013 Concrete, Class H	05/13/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455006	601.002.022 Concrete, Class DC		3.61	3.61	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last One Year of Data Slump Greater than or equal to 2 inches												
1463302	601.002.003 Concrete, Class B		2.87	2.87	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463302	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465013	601.002.013 Concrete, Class H		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901002	601.002.003 Concrete, Class B		0	0	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901005	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901008	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901011	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 09 Plant Name: BMC1.05.601 Central Supply F-13 @ Alta, WV

Last Inspection: 06/05/2019 Sticker Expires: 12/5/2019 Standard Deviation: 756.90 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1432591	601.002.003 Concrete, Class B		2.87	2.87	5							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Greater than or equal to 2 inches

1432591	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Less than 2 inches

1434176	601.002.015 Concrete, Class K		3.35	3.35	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Two Years of Data Slump Greater than or equal to 2 inches

1434176	601.002.015 Concrete, Class K		3.35	3.35	5							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last One Year of Data Slump Greater than or equal to 2 inches

1434176	601.002.015 Concrete, Class K		3.35	3.35	9							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1434221	601.002.003 Concrete, Class B		2.87	2.63	48	3000	1.5	3	797.18	5740	> 5391.54	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last One Year of Data Slump Greater than or equal to 2 inches												
1434221	601.002.003 Concrete, Class B		2.87	2.63	48	3000	1.5	3	797.18	5740	> 5391.54	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1434221	601.002.003 Concrete, Class B		2.87	2.87	6							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436459	601.002.023 Concrete, Class H-IC	02/19/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1436466	601.002.013 Concrete, Class H		3.45	3.45	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459801	679.002.002 Concrete, Microsilica		3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459810	601.002.002 Concrete, Class A Modified		3.60	3.60	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461849	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463335	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465019	601.002.004 Concrete, Class B Modified		3.12	3.12	19	3500	1.528	3.151	619.88	4447.18	< 5279.47	< 5453.24
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1465019	601.002.004 Concrete, Class B Modified		3.12	3.12	4							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901016	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901019	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901022	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor ($K1$)	Factor ($K2$)	Standard Deviation (s)	(F_c+K1s)	Average Strength(X)	(F_c+K2s)
1901025	601.002.001 Concrete, Class A		3.63	3.63	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 10

Plant Name: BMC1.06.601 Central Supply F-14 @ Beckley, WV

Last Inspection: 11/12/2019

Sticker Expires: 5/12/2020

Standard Deviation: 661.11

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1424532	679.002.002 Concrete, Microsilica	02/25/2018	3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1432573	601.002.003 Concrete, Class B		2.87	2.87	30	3000	1.501	3.008	840.96	4262.28 <	4801.33 <	5529.61
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
1432573	601.002.003 Concrete, Class B		2.87	2.87	189	3000	1.5	3	643.29	3964.94 <	4448.1 <	4929.87
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
1432573	601.002.003 Concrete, Class B		2.87	2.87	60	3000	1.5	3	693.81	4040.72 <	4576.22 <	5081.43
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1432589	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434174	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434223	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436460	601.002.023 Concrete, Class H-IC	02/14/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last One Year of Data Slump Greater than or equal to 2 inches												
1436464	601.002.013 Concrete, Class H		3.45	3.45	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436486	601.002.013 Concrete, Class H	05/13/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1459808	601.002.001 Concrete, Class A		3.60	3.60	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459829	501.002.003 Concrete, Roller Compacted		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1459835	601.002.004 Concrete, Class B Modified	06/06/2019	3.24	3.24	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last One Year of Data Slump Less than 2 inches												
1461847	601.002.022 Concrete, Class DC		3.59	3.59	1							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Less than 2 inches												
1463298	601.002.003 Concrete, Class B		2.87	2.87	3							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						
Last One Year of Data Slump Greater than or equal to 2 inches												
1463298	601.002.003 Concrete, Class B		2.87	2.63	32	3000	1.5	3	592.32	5170.16	> 4776.96	= 0.24
						DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901014	601.002.022 Concrete, Class DC		3.59	3.59	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901017	601.002.003 Concrete, Class B		2.87	2.87	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901020	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901023	601.002.001 Concrete, Class A		3.63	3.63	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 03 Plant Name: CCC1.01.601 Cardinal Concrete F-1 @ Ravenswood, WV
 Last Inspection: 06/26/2019 Sticker Expires: 12/26/2019 Standard Deviation: 662.25 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1398978	601.002.013 Concrete, Class H	12/29/2018	3.23	3.23	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1436396	601.002.003 Concrete, Class B		2.87	2.87	5							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						
Last One Year of Data Slump Greater than or equal to 2 inches												
1436396	601.002.003 Concrete, Class B		2.87	2.87	3							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455072	601.002.022 Concrete, Class DC	06/21/2019	3.74	3.74	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461784	679.002.002 Concrete, Microsilica		3.85	3.85	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
1461812	601.002.003 Concrete, Class B		2.87	2.63	17	3000	1.538	3.202	466.81	5335.29	> 4494.73	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last Two Years of Data Slump Greater than or equal to 2 inches												
1461812	601.002.003 Concrete, Class B		2.87	2.87	18	3000	1.533	3.175	789.72	4210.64	< 4855.56	< 5507.36
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
Last One Year of Data Slump Less than 2 inches												
1461812	601.002.003 Concrete, Class B		2.87	2.63	49	3000	1.5	3	815.55	5756.33	> 5446.65	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last One Year of Data Slump Greater than or equal to 2 inches												
1461812	601.002.003 Concrete, Class B		2.87	2.63	77	3000	1.5	3	655.94	5184.42	> 4967.82	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last Three Months of Data Slump Less than 2 inches												
1461812	601.002.003 Concrete, Class B		2.87	2.87	6							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461812	601.002.003 Concrete, Class B		2.87	2.87	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Less than 2 inches

1461816	601.002.015 Concrete, Class K		3.36	3.36	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

Last One Year of Data Slump Greater than or equal to 2 inches

1461816	601.002.015 Concrete, Class K		3.36	3.36	2							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1461820	601.002.022 Concrete, Class DC		3.74	3.74	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1461854	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 03

Plant Name: CCC1.02.601 Cardinal Concrete F-2 @ Parkersburg, WV

Last Inspection: 06/27/2019

Sticker Expires: 12/27/2019

Standard Deviation: 908.16

Rating: A-2

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Less than 2 inches

1432578	601.002.003 Concrete, Class B		2.92	2.92	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Two Years of Data Slump Greater than or equal to 2 inches

1432578	601.002.003 Concrete, Class B		2.92	2.92	22	3000	1.518	3.096	1038.78	4576.87	< 5282.27	< 6216.06
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

Last One Year of Data Slump Greater than or equal to 2 inches

1432578	601.002.003 Concrete, Class B		2.92	2.92	28	3000	1.505	3.024	797.54	4200.3	< 4548.21	< 5411.76
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1432579	601.002.003 Concrete, Class B	06/07/2019	2.89	2.89	6							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1455049	601.002.015 Concrete, Class K	02/11/2019	3.59	3.59	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459845	601.002.013 Concrete, Class H	12/29/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461785	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461813	601.002.003 Concrete, Class B		2.87	2.87	47	3000	1.5	3	1007.64	4511.46 <	5283.4 <	6022.92
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461817	601.002.015 Concrete, Class K		3.36	3.36	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor ($K1$)	Factor ($K2$)	Standard Deviation (s)	(F_c+K1s)	Average Strength(X)	(F_c+K2s)
1461821	601.002.022 Concrete, Class DC		3.74	3.74	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 04

Plant Name: CCC1.03.601 Cardinal Concrete F-3 @ Bridgeport, WV

Last Inspection: 09/10/2019

Sticker Expires: 3/10/2020

Standard Deviation: 566.58

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1434187	601.002.003		2.87	2.87	56	3000	1.5	3	567.48	3851.22	< 4679.82	< 4702.44
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Greater than or equal to 2 inches												
1434187	601.002.003		2.87	2.63	31	3000	1.5	3	436.16	4697.42	> 4308.48	= 0.24
	Concrete, Class B				DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1434187	601.002.003		2.87	2.87	1							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
1434188	601.002.015		3.35	3.35	3							
	Concrete, Class K				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1434188	601.002.015		3.35	3.35	2							
	Concrete, Class K				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
1434188	601.002.015		3.35	3.35	3							
	Concrete, Class K				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436458	601.002.004 Concrete, Class B Modified	01/28/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1455051	601.002.013 Concrete, Class H		3.45	3.45	8							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1455051	601.002.013 Concrete, Class H		3.45	3.45	7							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1455080	601.002.022 Concrete, Class DC	07/18/2019	3.74	3.74	11	4500	1.588	3.51	722.37	5647.12	< 6543.64	< 7035.52
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461786	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461822	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last One Year of Data Slump Greater than or equal to 2 inches												
1461855	601.002.022 Concrete, Class DC		3.74	3.74	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461855	601.002.022 Concrete, Class DC		3.74	3.74	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 04

Plant Name: CSC1.01.601 Central Supply F-1 @ Saltwell, WV

Last Inspection: 09/04/2019

Sticker Expires: 3/4/2020

Standard Deviation: 583.97

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1432544 601.002.013 **05/09/2019** 3.45 3.45 6
 Concrete, Class H

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1432553 679.002.002 **05/09/2019** 3.82 3.82 3
 Concrete, Microsilica

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last One Year of Data Slump Greater than or equal to 2 inches

1434196 601.002.003 2.87 2.87 6
 Concrete, Class B

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1434198 601.002.003 2.87 2.87 0
 Concrete, Class B

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434199	601.002.003 Concrete, Class B		2.87	2.63	10	3000	1.604	3.615	641.87	6198	> 5320.36	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
1434199	601.002.003 Concrete, Class B		2.87	2.87	93	3000	1.5	3	538.86	3808.29	< 4604.88	< 4616.58
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
1434199	601.002.003 Concrete, Class B		2.87	2.63	19	3000	1.528	3.151	431.6	5454.21	> 4359.97	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
1434199	601.002.003 Concrete, Class B		2.87	2.87	22	3000	1.518	3.096	693.49	4052.72	< 4779.09	< 5147.05
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
Last Three Months of Data Slump Less than 2 inches												
1434199	601.002.003 Concrete, Class B		2.87	2.87	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1434199	601.002.003 Concrete, Class B		2.87	2.63	14	3000	1.557	3.313	459.99	5119.29	> 4523.95	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1436403	601.002.015 Concrete, Class K		3.35	3.35	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436405	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1436419	601.002.001 Concrete, Class A		3.47	3.47	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436462	601.002.023 Concrete, Class H-IC	03/25/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1455036	601.002.022 Concrete, Class DC		3.58	3.58	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1455036	601.002.022 Concrete, Class DC		3.58	3.58	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1458960	601.002.016 Concrete, Class K Modified		3.47	3.47	6							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463247	601.002.001 Concrete, Class A		3.47	3.47	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463248	601.002.022 Concrete, Class DC		3.59	3.59	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463249	601.002.015 Concrete, Class K		3.35	3.35	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463250	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463251	601.002.013 Concrete, Class H		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463312	601.002.015 Concrete, Class K		3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463313	601.002.003 Concrete, Class B		2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901386	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901387	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 04

Plant Name: CSC1.02.601 Central Supply F-2 @ Westover, WV

Last Inspection: 09/05/2019

Sticker Expires: 3/5/2020

Standard Deviation: 685.35

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Less than 2 inches

1432523	601.002.003 Concrete, Class B		2.87	2.87	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last One Year of Data Slump Greater than or equal to 2 inches

1432523	601.002.003 Concrete, Class B		2.87	2.63	18	3000	1.533	3.175	474.17	5425.56	> 4505.49	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1432547	601.002.013 Concrete, Class H		3.45	3.45	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Greater than or equal to 2 inches

1432547	601.002.013 Concrete, Class H		3.45	3.21	10	4000	1.604	3.615	353.62	7545	> 5278.34	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1432552	679.002.002 Concrete, Microsilica	05/09/2019	3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1434192	601.002.003		2.87	2.87	1							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1434192	601.002.003		2.87	2.87	1							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Less than 2 inches												
1434193	601.002.003		2.87	2.63	20	3000	1.525	3.13	607.96	5700.85	> 4902.91	= 0.24
	Concrete, Class B				DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1434193	601.002.003		2.87	2.87	57	3000	1.5	3	758.81	4138.22	< 5158.44	< 5276.43
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Less than 2 inches												
1434193	601.002.003		2.87	2.87	7							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
1434193	601.002.003		2.87	2.87	29	3000	1.503	3.016	663.49	3997.23	< 4774.14	< 5001.09
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last Three Months of Data Slump Less than 2 inches												
1434193	601.002.003		2.87	2.87	6							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1434193	601.002.003		2.87	2.87	17	3000	1.538	3.202	625.9	3962.63	< 4694.88	< 5004.13
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1434195	601.002.001		3.47	3.47	2							
	Concrete, Class A				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Less than 2 inches												
1434195	601.002.001		3.47	3.47	1							
	Concrete, Class A				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1434195	601.002.001		3.47	3.47	19	3500	1.528	3.151	901.3	4877.19	< 5909.47	< 6340
	Concrete, Class A				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Three Months of Data Slump Less than 2 inches												
1436404	601.002.015		3.35	3.35	2							
	Concrete, Class K				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1436404	601.002.015		3.35	3.35	1							
	Concrete, Class K				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1436406	601.002.015		3.35	3.35	37	4000	1.5	3	706.19	5059.28	< 5858.27	< 6118.57
	Concrete, Class K				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Greater than or equal to 2 inches												
1436406	601.002.015		3.35	3.35	4							
	Concrete, Class K				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436463	601.002.023 Concrete, Class H-IC	03/26/2018	3.44	3.44	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455037	601.002.022 Concrete, Class DC		3.58	3.58	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458961	601.002.016 Concrete, Class K Modified		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459833	501.002.003 Concrete, Roller Compacted		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463260	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last One Year of Data Slump Greater than or equal to 2 inches												
1463267	601.002.003 Concrete, Class B		2.87	2.87	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463286	601.002.013 Concrete, Class H		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463287	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463288	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463310	601.002.015 Concrete, Class K		3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901391	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901395	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 08

Plant Name: CSC1.03.601 Central Supply F-3 @ Elkins, WV

Last Inspection: 09/30/2019

Sticker Expires: 3/30/2020

Standard Deviation: 651.06

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434201	601.002.003 Concrete, Class B		2.87	2.87	99	3000	1.5	3	714.07	4071.1	< 4727.88	< 5142.21
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
Last One Year of Data Slump Less than 2 inches												
1434201	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1434201	601.002.003 Concrete, Class B		2.87	2.63	54	3000	1.5	3	687.88	5087.96	> 5063.64	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last Three Months of Data Slump Less than 2 inches												
1434201	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1434201	601.002.003 Concrete, Class B		2.87	2.63	50	3000	1.5	3	695.35	5222.8	> 5086.05	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1434212	601.002.001 Concrete, Class A		3.47	3.47	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1434212	601.002.001 Concrete, Class A		3.47	3.47	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1434214	601.002.003 Concrete, Class B		2.87	2.87	9							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1434218	601.002.015 Concrete, Class K		3.35	3.35	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Three Months of Data Slump Greater than or equal to 2 inches

1434226	601.002.004 Concrete, Class B Modified		3.35	3.35	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1434230	601.002.016 Concrete, Class K Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434234	601.002.011 Concrete, Class D		2.04	2.04	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
1436389	601.002.015 Concrete, Class K		3.35	3.35	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Two Years of Data Slump Greater than or equal to 2 inches												
1436389	601.002.015 Concrete, Class K		3.35	3.35	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1436389	601.002.015 Concrete, Class K		3.35	3.35	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1436443	601.002.013 Concrete, Class H		3.45	3.45	11	4000	1.588	3.51	1003.45	5593.48	< 7269.09	< 7522.11
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
Last One Year of Data Slump Greater than or equal to 2 inches												
1436443	601.002.013 Concrete, Class H		3.45	3.21	29	4000	1.503	3.016	565.54	7095.52	> 5705.67	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1455042	601.002.022 Concrete, Class DC		3.59	3.59	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1459834	601.002.004 Concrete, Class B Modified		3.37	3.13	35	4000	1.5	3	637.41	6190	> 5912.23	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

Last One Year of Data Slump Greater than or equal to 2 inches												
1459834	601.002.004 Concrete, Class B Modified		3.37	3.13	16	4000	1.543	3.233	493.94	6299.38	> 5596.91	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1459837	601.002.003 Concrete, Class B		2.86	2.86	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459841	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459844	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1461800	679.002.002 Concrete, Microsilica		3.82	3.82	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1461800	679.002.002 Concrete, Microsilica		3.82	3.82	5							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461824	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461826	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461828	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461830	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461832	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461845	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463305	601.002.001 Concrete, Class A	03/09/2019	3.49	3.49	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463314	601.002.015 Concrete, Class K	03/09/2019	3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463319	601.002.003 Concrete, Class B	03/09/2019	2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465016	601.002.004 Concrete, Class B Modified		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901026	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901396	601.002.011 Concrete, Class D		2.03	2.03	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901400	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 07

Plant Name: CSC1.04.601 Central Supply F-4 @ Gassaway, WV

Last Inspection: 09/09/2019

Sticker Expires: 3/9/2020

Standard Deviation: 560.51

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1434202	601.002.003		2.87	2.63	31	3000	1.5	3	633.24	4968.06	> 4899.72	= 0.24
	Concrete, Class B				DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

Last One Year of Data Slump Greater than or equal to 2 inches

1434202	601.002.003		2.87	2.87	2							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

Last Three Months of Data Slump Greater than or equal to 2 inches

1434202	601.002.003		2.87	2.87	5							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1434215	601.002.003		2.87	2.63	14	3000	1.557	3.313	682.09	5545	> 5259.76	= 0.24
	Concrete, Class B				DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1434219	601.002.015		3.35	3.35	1							
	Concrete, Class K				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434228	601.002.004 Concrete, Class B Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434232	601.002.016 Concrete, Class K Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434235	601.002.011 Concrete, Class D		2.04	2.04	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436390	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436414	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436446	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Three Months of Data Slump Greater than or equal to 2 inches												
1455045	601.002.022 Concrete, Class DC		3.59	3.59	7							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1458980	679.002.002 Concrete, Microsilica		3.82	3.58	12	4000	1.576	3.429	354.99	8040	> 5217.26	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459840	601.002.003 Concrete, Class B		2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463307	601.002.001 Concrete, Class A	03/09/2019	3.49	3.49	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463316	601.002.015 Concrete, Class K	03/09/2019	3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463321	601.002.003 Concrete, Class B	03/09/2019	2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901028	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901398	601.002.011 Concrete, Class D		2.03	2.03	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901402	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 07

Plant Name: CSC1.05.601 Central Supply F-5 @ Glenville, WV

Last Inspection: 09/09/2019

Sticker Expires: 3/9/2020

Standard Deviation: 400.50

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1434203	601.002.003		2.87	2.87	15	3000	1.549	3.27	577.9	3895.17	< 4311.33	< 4889.73
	Concrete, Class B										MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26	

Last One Year of Data Slump Less than 2 inches

1434203	601.002.003		2.87	2.87	2							
	Concrete, Class B										MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA	

Last One Year of Data Slump Greater than or equal to 2 inches

1434203	601.002.003		2.87	2.87	11	3000	1.588	3.51	524.73	3833.27	< 4678.18	< 4841.8
	Concrete, Class B										MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26	

Last Three Months of Data Slump Greater than or equal to 2 inches

1434203	601.002.003		2.87	2.87	2							
	Concrete, Class B										MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA	

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last One Year of Data Slump Greater than or equal to 2 inches

1434216	601.002.003		2.87	2.87	1							
	Concrete, Class B										MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA	

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1434220	601.002.015		3.35	3.35	0							
	Concrete, Class K										MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA	

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434227	601.002.004 Concrete, Class B Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434231	601.002.016 Concrete, Class K Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434236	601.002.011 Concrete, Class D		2.04	2.04	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last One Year of Data Slump Less than 2 inches												
1436391	601.002.015 Concrete, Class K		3.35	3.35	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436415	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last One Year of Data Slump Greater than or equal to 2 inches												
1436445	601.002.013 Concrete, Class H		3.45	3.45	6							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1436445	601.002.013 Concrete, Class H		3.45	3.45	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455044	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458979	679.002.002 Concrete, Microsilica		3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459839	601.002.003 Concrete, Class B		2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459843	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463306	601.002.001 Concrete, Class A	03/09/2019	3.49	3.49	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463315	601.002.015 Concrete, Class K	03/09/2019	3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463320	601.002.003 Concrete, Class B	03/09/2019	2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901029	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901399	601.002.011 Concrete, Class D		2.03	2.03	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901403	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 03

Plant Name: CSC1.15.601 Central Supply F-15 @ Pennsboro, WV

Last Inspection: 09/11/2019

Sticker Expires: 3/11/2020

Standard Deviation: 627.68

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458974	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Less than 2 inches												
1458975	601.002.003 Concrete, Class B		2.87	2.87	5							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1458975	601.002.003 Concrete, Class B		2.87	2.63	20	3000	1.525	3.13	681.98	6578	> 5134.6	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Three Months of Data Slump Greater than or equal to 2 inches												
1458976	601.002.003 Concrete, Class B		2.86	2.86	11	3000	1.588	3.51	702.53	4115.62 <	5370.91 <	5465.88
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Greater than or equal to 2 inches												
1458976	601.002.003 Concrete, Class B		2.86	2.62	11	3000	1.588	3.51	586.74	5205.45 >	5059.46 =	0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Last Three Months of Data Slump Less than 2 inches												
1458976	601.002.003 Concrete, Class B		2.86	2.86	2							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1458976	601.002.003 Concrete, Class B		2.86	2.86	11	3000	1.588	3.51	702.53	4115.62 <	5370.91 <	5465.88
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458977	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458978	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459812	679.002.002 Concrete, Microsilica		3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463246	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463309	601.002.001 Concrete, Class A	03/09/2019	3.49	3.49	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463318	601.002.015 Concrete, Class K	03/09/2019	3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463323	601.002.003 Concrete, Class B	03/09/2019	2.88	2.88	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1464653	601.002.022 Concrete, Class DC	11/24/2018	3.59	3.59	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 08

Plant Name: CSC1.16.601 Central Supply F-16 @ Parsons, WV

Last Inspection: 11/01/2019

Sticker Expires: 5/1/2020

Standard Deviation: 541.81

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461825	601.002.003 Concrete, Class B		2.87	2.87	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461827	601.002.003 Concrete, Class B		2.87	2.87	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461829	601.002.015 Concrete, Class K		3.35	3.35	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461831	601.002.022 Concrete, Class DC		3.59	3.59	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461833	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461835	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461836	601.002.003 Concrete, Class B		2.86	2.86	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461837	601.002.004		3.37	3.37	11	5300	1.588	3.51	615.54	6040.91	< 6277.48	= 0
	Concrete, Class B Modified				INCREASE CEMENT FACTOR BY 0 PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Greater than or equal to 2 inches												
1461837	601.002.004		3.37	3.37	8							
	Concrete, Class B Modified				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461837	601.002.004		3.37	3.37	11	5300	1.588	3.51	615.54	6040.91	< 6277.48	= 0
	Concrete, Class B Modified				INCREASE CEMENT FACTOR BY 0 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1461838	601.002.022		3.59	3.59	0							
	Concrete, Class DC				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1461846	601.002.001		3.47	3.47	0							
	Concrete, Class A				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1465015	601.002.004 Concrete, Class B Modified		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1465021	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01

Plant Name: CSC2.01.601 Claxton Smith Concrete F-1 @ Poca, WV

Last Inspection: 09/12/2019

Sticker Expires: 3/12/2020

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1436474	501.002.001 Concrete, Pavement	04/21/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1436477	501.002.001 Concrete, Pavement	04/20/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1455053	601.002.022 Concrete, Class DC	03/13/2019	3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Last Two Years of Data Slump Greater than or equal to 2 inches												
1461805	601.002.003 Concrete, Class B		2.95	2.95	8							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 02 Plant Name: CSC2.02.601 Claxton Smith Concrete F-2 @ Culloden, WV
 Last Inspection: 10/25/2019 Sticker Expires: 4/25/2020 Standard Deviation: 650.00 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1436472	501.002.001 Concrete, Pavement	04/21/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1436475	501.002.002 Concrete, Pavement HES	04/20/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1455054	601.002.022 Concrete, Class DC	03/13/2019	3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1461804	601.002.003 Concrete, Class B		2.96	2.96	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01

Plant Name: CSC2.03.601 Claxton Smith Concrete F-3 @ Charleston, WV

Last Inspection: 09/11/2019

Sticker Expires: 3/11/2020

Standard Deviation: 606.02

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1436473	501.002.001 Concrete, Pavement	04/21/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1436476	501.002.002 Concrete, Pavement HES	04/20/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1455055	601.002.022 Concrete, Class DC	03/13/2019	3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1461803	601.002.003		2.96	2.96	32	3000	1.5	3	683.52	4025.28	< 4336.88	< 5050.56
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1461803	601.002.003		2.96	2.96	32	3000	1.5	3	683.52	4025.28	< 4336.88	< 5050.56
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Greater than or equal to 2 inches												
1461803	601.002.003		2.96	2.96	26	3000	1.508	3.044	555.26	3837.33	< 4664.62	< 4690.21
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last Three Months of Data Slump Less than 2 inches												
1461803	601.002.003		2.96	2.96	3							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461803	601.002.003		2.96	2.72	10	3000	1.604	3.615	444.35	4644	> 4606.33	= 0.24
	Concrete, Class B				DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

District: 06

Plant Name: DCC1.01.601 D.W. Dickey Concrete @ Steubenville, OH

Last Inspection: 09/19/2019

Sticker Expires: 3/19/2020

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
1399046	601.002.003		2.87	2.87	1							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1399046	601.002.003		2.87	2.87	4							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 05

Plant Name: DCX1.01.601 Dan Lee Co. F-1 @ Inwood, WV (Transit)

Last Inspection: 09/17/2019

Sticker Expires: 3/17/2020

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	--------------------------	------------------	------------------	----------------------------	-------------------------	----------------	--------------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1458943	601.002.003 Concrete, Class B	10/05/2019	2.87	2.87	1	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						
---------	----------------------------------	------------	------	------	---	---	--	--	--	--	--	--

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 10

Plant Name: DHC1.02.601 Central Supply @ Mabscott, WV

Last Inspection: 11/12/2019

Sticker Expires: 5/12/2020

Standard Deviation: 499.83

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1458992 601.002.003 2.87 2.63 14 3000 1.557 3.313 405.31 5307.86 > 4342.79 = 0.24

Concrete, Class B

DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26
--

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1458993 601.002.015 3.35 3.35 3

Concrete, Class K

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1459836 601.002.022 3.74 3.74 6

Concrete, Class DC

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1461802 601.002.013 3.45 3.45 5

Concrete, Class H

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463296	601.002.003 Concrete, Class B	06/06/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463297	601.002.013 Concrete, Class H	03/19/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1463299	601.002.003 Concrete, Class B		2.87	2.87	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Less than 2 inches												
1463299	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463300	601.002.015 Concrete, Class K		3.35	3.35	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
1465068	601.002.022 Concrete, Class DC		3.59	3.59	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 10 Plant Name: ECI1.01.601 Eastern Concrete Pinville WV
 Last Inspection: 10/15/2019 Sticker Expires: 4/15/2020 Standard Deviation: 752.69 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	-------------------------

Last One Year of Data Slump Greater than or equal to 2 inches

1463324	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Greater than or equal to 2 inches

1463324	601.002.003 Concrete, Class B		2.87	2.87	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	-------------------------

Last One Year of Data Slump Greater than or equal to 2 inches

1463325	501.002.001 Concrete, Pavement		2.87	2.87	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Less than 2 inches

1463325	501.002.001 Concrete, Pavement		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Greater than or equal to 2 inches

1463325	501.002.001 Concrete, Pavement		2.87	2.87	29	4300	1.503	3.016	733	4976.55	< 5401.7	= 0
INCREASE CEMENT FACTOR BY 0 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	-------------------------

Last Three Months of Data Slump Greater than or equal to 2 inches

1463326	601.002.015 Concrete, Class K		3.35	3.35	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463327	601.002.022 Concrete, Class DC		3.74	3.74	9							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463328	601.002.013 Concrete, Class H		3.45	3.45	4							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1465023	601.002.003 Concrete, Class B		2.87	2.87	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1465024	501.002.001 Concrete, Pavement		2.87	2.87	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01

Plant Name: ERM1.02.601 Hanson Ready Mix F-2 @ Gallipolis, OH

Last Inspection: 07/18/2019

Sticker Expires: 1/18/2020

Standard Deviation: 480.84

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1459802	601.002.013 Concrete, Class H		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459811	601.002.003 Concrete, Class B	03/11/2019	2.87	2.87	15	3000	1.549	3.27	617.35	3956.28	< 4438	< 5018.73
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
1459811	601.002.003 Concrete, Class B	03/11/2019	2.87	2.63	10	3000	1.604	3.615	302.91	4470	> 4095.02	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1459827	601.002.013 Concrete, Class H		3.45	3.45	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459831	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461797	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1461842	601.002.015 Concrete, Class K		3.35	3.35	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465029	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465032	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465037	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465042	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465047	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465052	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465061	601.002.022 Concrete, Class DC		3.72	3.72	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 06

Plant Name: ERM1.03.601 Hanson Ready Mix F-3 @ New Martinsville, WV

Last Inspection: 05/15/2019

Sticker Expires: 11/15/2019

Standard Deviation: 599.56

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1455087	601.002.013 Concrete, Class H	07/26/2019	3.45	3.45	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1455089	601.002.015 Concrete, Class K	08/01/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1458939	679.002.002 Concrete, Microsilica	08/22/2019	3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor ($K1$)	Factor ($K2$)	Standard Deviation (s)	Average Strength(X)	(F_c+K2s)	$X-(F_c+K1s)/1.4$
Last One Year of Data Slump Less than 2 inches												
1461780	601.002.015 Concrete, Class K		3.41	3.41	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1461780	601.002.015 Concrete, Class K		3.41	3.41	8							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Less than 2 inches												
1461780	601.002.015 Concrete, Class K		3.41	3.41	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
1461798	601.002.003 Concrete, Class B		2.87	2.87	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1461798	601.002.003 Concrete, Class B		2.87	2.87	35	3000	1.5	3	654.59	3981.88	< 4239.43	< 4963.77
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Less than 2 inches												
1461798	601.002.003 Concrete, Class B		2.87	2.87	2							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
1461798	601.002.003 Concrete, Class B		2.87	2.63	42	3000	1.5	3	665.87	5007.62	> 4997.61	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Last Three Months of Data Slump Less than 2 inches												
1461798	601.002.003 Concrete, Class B		2.87	2.87	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461798	601.002.003 Concrete, Class B		2.87	2.87	4							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1461823	601.002.022 Concrete, Class DC		3.75	3.75	5							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
1461823	601.002.022 Concrete, Class DC		3.75	3.75	4							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1463259	601.002.013 Concrete, Class H		3.45	3.45	2							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						
Last One Year of Data Slump Greater than or equal to 2 inches												
1463259	601.002.013 Concrete, Class H		3.45	3.45	2							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463259	601.002.013 Concrete, Class H		3.45	3.45	5							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465083	601.002.013 Concrete, Class H		3.45	3.45	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901032	601.002.003 Concrete, Class B		2.87	2.87	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901034	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901036	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901038	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901040	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 06

Plant Name: ERM1.04.601 Hanson Ready Mix F-4 @ McMechen WV

Last Inspection: 05/15/2019

Sticker Expires: 11/15/2019

Standard Deviation: 642.69

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1461779	601.002.022 Concrete, Class DC		3.75	3.75	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last One Year of Data Slump Greater than or equal to 2 inches

1461779	601.002.022 Concrete, Class DC		3.75	3.75	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1461781	601.002.015 Concrete, Class K		3.35	3.35	6							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last One Year of Data Slump Less than 2 inches

1461781	601.002.015 Concrete, Class K		3.35	3.35	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Less than 2 inches

1461781	601.002.015 Concrete, Class K		3.35	3.35	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Greater than or equal to 2 inches

1461781	601.002.015 Concrete, Class K		3.35	3.35	14	4000	1.557	3.313	547.73	4852.82	<	5205	<	5814.63
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26														

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Less than 2 inches												
1461799	601.002.003 Concrete, Class B		2.87	2.87	5							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1461799	601.002.003 Concrete, Class B		2.87	2.87	49	3000	1.5	3	620.22	3930.33	< 4597.76	< 4860.66
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Greater than or equal to 2 inches												
1461799	601.002.003 Concrete, Class B		2.87	2.87	25	3000	1.511	3.055	821.84	4241.8	< 5055.6	< 5510.72
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last Three Months of Data Slump Less than 2 inches												
1461799	601.002.003 Concrete, Class B		2.87	2.87	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461799	601.002.003 Concrete, Class B		2.87	2.63	17	3000	1.538	3.202	481.32	5157.65	> 4541.19	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1463258	601.002.013 Concrete, Class H		3.45	3.45	4							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
1463258	601.002.013 Concrete, Class H		3.45	3.45	9							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463258	601.002.013 Concrete, Class H		3.45	3.45	8							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465082	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901031	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901033	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901035	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901037	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901039	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01

Plant Name: ERM1.05.601 Hanson Ready Mix F-5 @ Winfield, WV

Last Inspection: 09/03/2019

Sticker Expires: 3/3/2020

Standard Deviation: 638.10

Rating: A-1

----- Evaluation of Cement Requirements -----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Greater than or equal to 2 inches

1424567	601.002.004 Concrete, Class B Modified	03/11/2019	3.34	2.87	38	3000	1.5	3	755.6	4133.4 <	4884.21 <	5266.8
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements -----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Less than 2 inches

1424572	601.002.003 Concrete, Class B	03/11/2019	2.87	2.87	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

Last Two Years of Data Slump Greater than or equal to 2 inches

1424572	601.002.003 Concrete, Class B	03/11/2019	2.87	2.87	38	3000	1.5	3	755.6	4133.4 <	4884.21 <	5266.8
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements -----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last One Year of Data Slump Greater than or equal to 2 inches

1424599	601.002.013 Concrete, Class H		3.45	3.45	4							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

-----< Evaluation of Cement Requirements >-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Less than 2 inches												
1436421	601.002.003 Concrete, Class B		2.87	2.87	7							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1436421	601.002.003 Concrete, Class B		2.87	2.87	40	3000	1.5	3	771.71	4157.57	< 4785	< 5315.13
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Less than 2 inches												
1436421	601.002.003 Concrete, Class B		2.87	2.87	2							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
1436421	601.002.003 Concrete, Class B		2.87	2.87	16	3000	1.543	3.233	858.47	4324.62	< 5301.25	< 5775.43
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1436421	601.002.003 Concrete, Class B		2.87	2.87	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----< Evaluation of Cement Requirements >-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436426	601.002.022 Concrete, Class DC		3.73	3.73	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----< Evaluation of Cement Requirements >-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455029	601.002.014 Concrete, Class H Modified	09/03/2018	3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Less than 2 inches

1458948	601.002.015 Concrete, Class K		3.83	3.83	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Two Years of Data Slump Greater than or equal to 2 inches

1458948	601.002.015 Concrete, Class K		3.83	3.83	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	-------------------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1459006	601.002.015 Concrete, Class K		3.39	3.39	22	4000	1.518	3.096	540.85	4821.01	< 4929.09	< 5674.47
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

Last One Year of Data Slump Less than 2 inches

1459006	601.002.015 Concrete, Class K		3.39	3.39	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last One Year of Data Slump Greater than or equal to 2 inches

1459006	601.002.015 Concrete, Class K		3.39	3.39	14	4000	1.557	3.313	676.51	4756.43	< 5053.33	= 0
INCREASE CEMENT FACTOR BY 0 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1459828	601.002.013 Concrete, Class H		3.45	3.21	72	4000	1.5	3	663.85	7606.81	> 5991.55	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

Last One Year of Data Slump Greater than or equal to 2 inches

1459828	601.002.013 Concrete, Class H		3.45	3.21	15	4000	1.549	3.27	429.42	7228	> 5404.2	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1459832	601.002.013 Concrete, Class H		3.45	3.45	5							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1461792	601.002.003 Concrete, Class B		2.87	2.87	49	3000	1.5	3	546.25	3819.38	< 4038.16	< 4638.75
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
Last One Year of Data Slump Less than 2 inches												
1461792	601.002.003 Concrete, Class B		2.87	2.87	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1461792	601.002.003 Concrete, Class B		2.87	2.87	35	3000	1.5	3	865.76	4298.64	< 4598.29	< 5597.28
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461794	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Less than 2 inches

1461839	601.002.015 Concrete, Class K		3.35	3.35	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

Last Two Years of Data Slump Greater than or equal to 2 inches

1461839	601.002.015 Concrete, Class K		3.35	3.35	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1465027	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1465030	601.002.013 Concrete, Class H		3.45	3.45	6							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

Last Three Months of Data Slump Greater than or equal to 2 inches

1465030	601.002.013 Concrete, Class H		3.45	3.21	22	4000	1.518	3.096	391.42	8830.91	> 5211.84	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Three Months of Data Slump Greater than or equal to 2 inches												
1465034	601.002.003 Concrete, Class B		2.87	2.63	16	3000	1.543	3.233	679.25	5562.5	> 5196.02	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Three Months of Data Slump Greater than or equal to 2 inches												
1465039	601.002.003 Concrete, Class B		2.87	2.63	10	3000	1.604	3.615	561.45	5614	> 5029.64	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Three Months of Data Slump Less than 2 inches												
1465044	601.002.015 Concrete, Class K		3.35	3.35	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Three Months of Data Slump Less than 2 inches												
1465049	601.002.015 Concrete, Class K		3.35	3.35	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1465049	601.002.015 Concrete, Class K		3.35	3.35	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
Last Three Months of Data Slump Greater than or equal to 2 inches												
1465058	601.002.022 Concrete, Class DC		3.72	3.72	1	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 03

Plant Name: ERM1.06.601 Hanson Ready Mix F-6 @ Parkersburg, WV

Last Inspection: 08/22/2019

Sticker Expires: 2/22/2020

Standard Deviation: 523.21

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Less than 2 inches

1436399	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Two Years of Data Slump Greater than or equal to 2 inches

1436399	601.002.003 Concrete, Class B		2.87	2.87	111	3000	1.5	3	583.13	3874.7	< 4048.38	< 4749.39
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

Last One Year of Data Slump Greater than or equal to 2 inches

1436399	601.002.003 Concrete, Class B		2.87	2.87	20	3000	1.525	3.13	548.81	3836.94	< 4211	< 4717.78
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1455027	601.002.023 Concrete, Class H-IC	09/07/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1455050	601.002.022 Concrete, Class DC	02/21/2019	3.73	3.73	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1455090	601.002.013 Concrete, Class H	08/02/2019	3.45	3.21	10	4000	1.604	3.615	759.08	6857	> 6744.07	= 0.24
---------	----------------------------------	------------	------	------	----	------	-------	-------	--------	------	-----------	--------

DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
--	--	--	--	--	--	--	--	--	--	--	--	--

Last One Year of Data Slump Greater than or equal to 2 inches

1455090	601.002.013 Concrete, Class H	08/02/2019	3.45	3.45	7							
---------	----------------------------------	------------	------	------	---	--	--	--	--	--	--	--

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1461834	601.002.015 Concrete, Class K		3.35	3.35	0							
---------	----------------------------------	--	------	------	---	--	--	--	--	--	--	--

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1463257	601.002.015 Concrete, Class K		3.35	3.35	5							
---------	----------------------------------	--	------	------	---	--	--	--	--	--	--	--

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1463304	601.002.003 Concrete, Class B		2.87	2.63	12	4141	1.576	3.429	235.45	4970	> 4948.36	= 0.24
---------	----------------------------------	--	------	------	----	------	-------	-------	--------	------	-----------	--------

DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
--	--	--	--	--	--	--	--	--	--	--	--	--

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1465020	601.002.013 Concrete, Class H		3.45	3.45	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Greater than or equal to 2 inches

1465020	601.002.013 Concrete, Class H		3.45	3.45	6							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Less than 2 inches

1465053	601.002.015 Concrete, Class K		3.35	3.35	5							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last One Year of Data Slump Greater than or equal to 2 inches

1465053	601.002.015 Concrete, Class K		3.35	3.35	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Less than 2 inches

1465053	601.002.015 Concrete, Class K		3.35	3.35	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1465054	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465055	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1465056	601.002.003 Concrete, Class B		2.87	2.87	8							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Less than 2 inches												
1465056	601.002.003 Concrete, Class B		2.87	2.87	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1465056	601.002.003 Concrete, Class B		2.87	2.63	27	3000	1.507	3.034	431.49	4456.3	> 4309.14	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1465072	601.002.003 Concrete, Class B		2.87	2.87	6							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1465072	601.002.003 Concrete, Class B		2.87	2.87	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01

Plant Name: ERM1.07.601 Hanson Ready Mix F-7 @ Charleston, WV

Last Inspection: 09/10/2019

Sticker Expires: 3/10/2020

Standard Deviation: 522.39

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1424571	601.002.003 Concrete, Class B	03/11/2019	2.87	2.87	9							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1424600	601.002.013 Concrete, Class H	02/13/2019	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1432540	679.002.002 Concrete, Microsilica		3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1436420	601.002.003 Concrete, Class B		2.87	2.87	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436453	601.002.022 Concrete, Class DC		3.73	3.73	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436478	601.002.016 Concrete, Class K Modified	04/20/2018	4.07	4.07	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436479	601.002.015 Concrete, Class K	04/21/2018	4.07	4.07	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436480	601.002.003 Concrete, Class B		4.07	4.07	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436481	601.002.003 Concrete, Class B		4.07	4.07	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455088	679.002.002 Concrete, Microsilica	07/27/2019	3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458950	601.002.015 Concrete, Class K		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1459008	601.002.015 Concrete, Class K		3.39	3.39	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1459826	601.002.013 Concrete, Class H		3.45	3.21	22	4000	1.518	3.096	563.28	8828.64	> 5743.91	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1459830	601.002.013 Concrete, Class H		3.45	3.21	13	4000	1.565	3.365	509.3	8339.23	> 5713.79	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461796	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461841	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465025	601.002.013 Concrete, Class H		3.45	3.21	26	4000	1.508	3.044	519.92	8553.85	> 5582.64	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1465025	601.002.013 Concrete, Class H		3.45	3.45	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Three Months of Data Slump Greater than or equal to 2 inches												
1465026	601.002.013 Concrete, Class H		3.45	3.45	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465033	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465038	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465043	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465048	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465057	601.002.022 Concrete, Class DC		3.72	3.72	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 02

Plant Name: ERM1.08.601 Hanson Ready Mix F-8 @ Huntington, WV

Last Inspection: 11/11/2019

Sticker Expires: 5/11/2020

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458946	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458947	601.002.015 Concrete, Class K		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459005	601.002.015 Concrete, Class K		3.39	3.39	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1463334	601.002.003 Concrete, Class B		2.87	2.87	4							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

Last One Year of Data Slump Greater than or equal to 2 inches

1463334	601.002.003 Concrete, Class B		2.87	2.87	3							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1465028	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1465031	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1465036	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465041	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465046	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465051	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465060	601.002.022 Concrete, Class DC		3.72	3.72	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01

Plant Name: ERM1.09.601 Hanson Ready Mix F-9 @ Winfield, WV (Transit)

Last Inspection: 09/03/2019

Sticker Expires: 3/3/2020

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458949	601.002.015 Concrete, Class K		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
1459007	601.002.015 Concrete, Class K		3.39	3.39	5							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461793	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461795	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461840	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465035	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465040	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465045	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465050	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465059	601.002.022 Concrete, Class DC		3.72	3.72	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 05

Plant Name: FCC1.01.601 Fairfax Concrete F-1 @ Scherr WV

Last Inspection: 09/09/2019

Sticker Expires: 3/9/2020

Standard Deviation: 743.17

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421095	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421097	601.002.004 Concrete, Class B Modified	06/20/2019	3.33	3.33	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1421098	601.002.003 Concrete, Class B	08/21/2019	2.86	2.62	14	3000	1.557	3.313	715.79	6585.07	> 5371.41	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last One Year of Data Slump Greater than or equal to 2 inches												
1421098	601.002.003 Concrete, Class B	08/21/2019	2.86	2.86	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
1421100	601.002.015 Concrete, Class K		3.33	3.33	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1421100	601.002.015 Concrete, Class K		3.33	3.33	8							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
1421100	601.002.015 Concrete, Class K		3.33	3.33	3							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1421102	601.002.013 Concrete, Class H		3.44	3.44	7							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1432581	601.002.003 Concrete, Class B	06/07/2019	2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455035	601.002.023 Concrete, Class H-IC	10/14/2018	3.46	3.46	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455046	601.002.023 Concrete, Class H-IC	01/27/2019	3.43	3.43	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455076	601.002.003 Concrete, Class B	07/17/2019	2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458971	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463272	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Less than 2 inches												
1463275	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1463275	601.002.003 Concrete, Class B		2.87	2.87	9							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463275	601.002.003 Concrete, Class B		2.87	2.63	14	4356	1.557	3.313	687.93	6759.14	> 6635.11	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463278	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
1463281	601.002.013 Concrete, Class H		3.44	3.44	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 08 Plant Name: FCC1.02.601 Fairfax Concrete F-2 @ Oakland, MD
 Last Inspection: 09/10/2019 Sticker Expires: 3/10/2020 Standard Deviation: 650.00 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1424543	601.002.015 Concrete, Class K		3.33	3.33	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1424584	601.002.003 Concrete, Class B	03/11/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1432582	601.002.003 Concrete, Class B	08/23/2019	2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1455034	601.002.023 Concrete, Class H-IC	10/14/2018	3.46	3.46	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455048	601.002.023 Concrete, Class H-IC	01/27/2019	3.43	3.43	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455075	601.002.003 Concrete, Class B	07/17/2019	2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1458973	601.002.022 Concrete, Class DC		3.59	3.59	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1463274	601.002.003 Concrete, Class B		2.87	2.87	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463277	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463280	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463283	601.002.013 Concrete, Class H		3.44	3.44	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 08

Plant Name: FCC1.04.601 Fairfax Concrete F-4 @ Thomas WV

Last Inspection: 09/10/2019

Sticker Expires: 3/10/2020

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1424542 601.002.015
Concrete, Class K 3.33 3.33

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1424583 601.002.013
Concrete, Class H 3.44 3.44

3

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1432580 601.002.003 **06/07/2019** 2.87 2.87

2

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1455033 601.002.023 **10/14/2018** 3.46 3.46

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455047	601.002.023 Concrete, Class H-IC	01/27/2019	3.43	3.43	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455074	601.002.003 Concrete, Class B	07/17/2019	2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458972	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1463273	601.002.003 Concrete, Class B		2.87	2.87	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463273	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463276	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463279	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463282	601.002.013 Concrete, Class H		3.44	3.44	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 05

Plant Name: FCC1.05.601

Allegheny Concrete F-5 W Short Gap WV (Transit

Last Inspection: 09/10/2019

Sticker Expires: 3/10/2020

Standard Deviation: 447.23

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436470	601.002.023 Concrete, Class H-IC	04/02/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455028	601.002.023 Concrete, Class H-IC	09/07/2018	3.46	3.46	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1461806	601.002.004 Concrete, Class B Modified		3.34	3.34	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
1461807	601.002.003		2.87	2.87	3							
	Concrete, Class B											
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1461807	601.002.003		2.87	2.87	5							
	Concrete, Class B											
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461807	601.002.003		2.87	2.87	2							
	Concrete, Class B											
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Three Months of Data Slump Less than 2 inches												
1461808	601.002.015		3.35	3.35	2							
	Concrete, Class K											
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461808	601.002.015		3.35	3.35	1							
	Concrete, Class K											
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1463284	601.002.013		3.45	3.45	2							
	Concrete, Class H											
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 09

Plant Name: GRM1.01.601 Greenbrier Ready Mix, Caldwell WV

Last Inspection: 06/07/2019

Sticker Expires: 12/7/2019

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1459803 601.002.003
Concrete, Class B

2.87 2.87

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1459814 601.002.015
Concrete, Class K

3.35 3.35

1

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1459816 601.002.003
Concrete, Class B

2.87 2.87

5

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1463268 601.002.022
Concrete, Class DC

3.59 3.59

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
1463270	601.002.013 Concrete, Class H		3.47	3.47	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 10

Plant Name: JRM1.01.601 Jowar Ready Mix @ laeger, WV

Last Inspection: 09/04/2019

Sticker Expires: 3/4/2020

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455052	601.002.003 Concrete, Class B	02/28/2019	2.87	2.87	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463261	601.002.003 Concrete, Class B		2.87	2.87	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463262	601.002.015 Concrete, Class K		3.35	3.35	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463339	601.002.003 Concrete, Class B		3.23	3.23	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463340	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1463341	601.002.003 Concrete, Class B		3.23	3.23	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463342	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 10 Plant Name: KCX1.03.601 Kokosing Construction Company F-3 @ Sophia,
 Last Inspection: 06/13/2019 Sticker Expires: 12/13/2019 Standard Deviation: 584.09 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last One Year of Data Slump Less than 2 inches												
1463343	501.002.001 Concrete, Pavement		2.87	2.87	46	3000	1.5	3	723.75	4085.62 <	5115 <	5171.25
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Greater than or equal to 2 inches												
1463343	501.002.001 Concrete, Pavement		2.87	2.87	4							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Less than 2 inches												
1463343	501.002.001 Concrete, Pavement		2.87	2.63	38	3000	1.5	3	513.9	5407.11 >	4541.7 =	0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463343	501.002.001 Concrete, Pavement		2.87	2.87	2							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465017	501.002.001 Concrete, Pavement		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465062	501.002.001 Concrete, Pavement		2.87	2.63	44	3000	1.5	3	486.53	5300.91 >	4459.59 =	0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
1465063	501.002.001 Concrete, Pavement		2.88	2.88	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 02 Plant Name: LCC1.01.601 Logan Concrete F-1 @ Logan, WV
 Last Inspection: 08/09/2019 Sticker Expires: 2/9/2020 Standard Deviation: 650.00 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455065	601.002.003 Concrete, Class B	03/22/2019	2.89	2.89	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455066	601.002.015 Concrete, Class K	03/21/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455067	601.002.022 Concrete, Class DC	03/22/2019	3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455068	601.002.013 Concrete, Class H	03/21/2019	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461782	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461810	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461814	601.002.015 Concrete, Class K		3.36	3.36	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Three Months of Data Slump Greater than or equal to 2 inches												
1461818	601.002.022 Concrete, Class DC		3.74	3.74	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461850	501.002.001 Concrete, Pavement		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461852	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01

Plant Name: MRM2.01.601 Logan Concrete, Inc. - Madison Plant @ Madiso

Last Inspection: 10/23/2019

Sticker Expires: 4/23/2020

Standard Deviation: 688.71

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436409	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436410	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436482	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436483	601.002.004 Concrete, Class B Modified	05/06/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455030	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461783	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1461811	601.002.003 Concrete, Class B		2.87	2.87	5							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1461811	601.002.003 Concrete, Class B		2.87	2.87	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Less than 2 inches

1461815	601.002.015 Concrete, Class K		3.36	3.36	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Two Years of Data Slump Greater than or equal to 2 inches

1461815	601.002.015 Concrete, Class K		3.36	3.36	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1461819	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1461851	501.002.001 Concrete, Pavement		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1461853	601.002.013 Concrete, Class H		3.45	3.45	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01

Plant Name: MRM3.01.601 Mozack Ready Mix, Winfield WV

Last Inspection: 09/30/2019

Sticker Expires: 3/30/2020

Standard Deviation: 447.03

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Less than 2 inches

1458937	601.002.003	08/21/2019	2.87	2.87	1							
	Concrete, Class B											
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Two Years of Data Slump Greater than or equal to 2 inches

1458937	601.002.003	08/21/2019	2.87	2.87	39	3000	1.5	3	527.07	3790.6	< 4337.44	< 4581.21
	Concrete, Class B											
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

Last One Year of Data Slump Greater than or equal to 2 inches

1458937	601.002.003	08/21/2019	2.87	2.87	12	3000	1.576	3.429	359.78	3567.01	< 4103.33	< 4233.69
	Concrete, Class B											
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Last Two Years of Data Slump Less than 2 inches

1458938	601.002.015	08/21/2019	3.35	3.35	3							
	Concrete, Class K											
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Two Years of Data Slump Greater than or equal to 2 inches

1458938	601.002.015	08/21/2019	3.35	3.35	1							
	Concrete, Class K											
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1458994	601.002.003		4.07	4.07	0							
	Concrete, Class B											
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459003	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Greater than or equal to 2 inches												
1459004	601.002.013 Concrete, Class H		3.45	3.45	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459824	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459825	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463252	601.002.015 Concrete, Class K		3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463253	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463254	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463255	601.002.003 Concrete, Class B		2.89	2.89	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463256	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465069	601.002.003 Concrete, Class B		2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465070	601.002.015 Concrete, Class K		3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465071	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901001	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

District: 09 **Plant Name:** PCI1.01.601 Pro Contracting INC
Last Inspection: 08/08/2019 **Sticker Expires:** 2/8/2020 **Standard Deviation:** 650.00 **Rating:** A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463295	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01 Plant Name: RRM1.01.601 Rumble Ready Mix F-1 @ Winfield, WV
 Last Inspection: 11/12/2019 Sticker Expires: 5/12/2020 Standard Deviation: 551.73 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1455041	601.002.016	08/07/2019	3.35	3.11	12	3000	1.576	3.429	117.33	8587.5	> 3402.32	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1455099	501.002.002	08/07/2019	3.35	3.11	12	3000	1.576	3.429	117.33	8587.5	> 3402.32	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last Two Years of Data Slump Less than 2 inches												
1458929	601.002.003	08/08/2019	2.87	2.87	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1458929	601.002.003	08/08/2019	2.87	2.87	13	3000	1.565	3.365	1011.82	4583.5	< 4759.23	< 6404.77
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Less than 2 inches												
1458929	601.002.003	08/08/2019	2.87	2.87	6							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
1458929	601.002.003	08/08/2019	2.87	2.87	3							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458931	601.002.022 Concrete, Class DC	08/15/2019	3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458933	601.002.015 Concrete, Class K	08/15/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458935	601.002.013 Concrete, Class H	08/17/2019	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Last Two Years of Data Slump Less than 2 inches												
1458962	601.002.003 Concrete, Class B		2.87	2.87	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Two Years of Data Slump Greater than or equal to 2 inches												
1458962	601.002.003 Concrete, Class B		2.87	3.87	14	4300	1.557	3.313	740.2	4250.71	< 5452.49	= 1
					INCREASE CEMENT FACTOR BY 1 PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Less than 2 inches												
1458962	601.002.003 Concrete, Class B		2.87	2.87	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
1458962	601.002.003 Concrete, Class B		2.87	2.87	6							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Less than 2 inches												
1458962	601.002.003 Concrete, Class B		2.87	2.87	1							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458964	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458966	601.002.024 Concrete, Class B w/ Fly Ash		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458968	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458982	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458984	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458988	501.002.002 Concrete, Pavement HES		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor ($K1$)	Factor ($K2$)	Standard Deviation (s)	Average Strength(X)	(F_c+K1s)	(F_c+K1s)- $X/1.4$ Increase
1458990	601.002.022 Concrete, Class DC		3.59	3.59	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01

Plant Name: RRM1.02.601 Rumble Ready Mix F-2 @ Belle, WV

Last Inspection: 10/05/2018

Sticker Expires: 4/5/2019

Standard Deviation: 650.00

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1455100	501.002.002 Concrete, Pavement HES	08/08/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Last Two Years of Data Slump Greater than or equal to 2 inches												
1458930	601.002.003 Concrete, Class B	08/08/2019	2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458932	601.002.022 Concrete, Class DC	08/15/2019	3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458934	601.002.015 Concrete, Class K	08/15/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458936	601.002.013 Concrete, Class H	08/18/2019	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458963	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458965	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458967	601.002.024 Concrete, Class B w/ Fly Ash		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458969	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458983	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458985	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1458989	501.002.002 Concrete, Pavement HES		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_1s)	(F_c+K_1s)- $X/1.4$ Increase
1458991	601.002.022 Concrete, Class DC		3.59	3.59	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 03

Plant Name: SCC1.01.601 Smith Concrete F-1 @ Porterfield, OH

Last Inspection: 04/15/2019

Sticker Expires: 10/15/2019

Standard Deviation: 648.85

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Last Two Years of Data Slump Less than 2 inches												
1455069	601.002.003 Concrete, Class B	04/03/2019	2.89	2.89	1							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						
Last Two Years of Data Slump Greater than or equal to 2 inches												
1455069	601.002.003 Concrete, Class B	04/03/2019	2.89	2.89	4							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						
Last One Year of Data Slump Greater than or equal to 2 inches												
1455069	601.002.003 Concrete, Class B	04/03/2019	2.89	2.89	4							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Last One Year of Data Slump Less than 2 inches												
1463289	601.002.003 Concrete, Class B		2.87	2.87	1							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						
Last One Year of Data Slump Greater than or equal to 2 inches												
1463289	601.002.003 Concrete, Class B		2.87	2.87	10	3861	1.604	3.615	811.05	4994	< 5161.92	= 0
						INCREASE CEMENT FACTOR BY 0 PER SECTION 3.3 OF MP 711.03.26						
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463289	601.002.003 Concrete, Class B		2.87	2.87	8							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 03 Plant Name: SCC1.02.601 Smith Concrete F-2 @ Reno, OH
 Last Inspection: 08/21/2019 Sticker Expires: 2/21/2020 Standard Deviation: 727.81 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1455070	601.002.003 Concrete, Class B	04/03/2019	2.91	2.91	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Last One Year of Data Slump Greater than or equal to 2 inches												
1463290	601.002.003 Concrete, Class B		2.87	2.87	9							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Greater than or equal to 2 inches												
1463290	601.002.003 Concrete, Class B		2.87	2.87	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Last One Year of Data Slump Greater than or equal to 2 inches												
1463330	601.002.022 Concrete, Class DC		3.73	3.73	10	5800	1.604	3.615	815.87	6387	< 7108.66	= 0
INCREASE CEMENT FACTOR BY 0 PER SECTION 3.3 OF MP 711.03.26												

Last Three Months of Data Slump Greater than or equal to 2 inches												
1463330	601.002.022 Concrete, Class DC		3.73	3.73	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1463333	601.002.009 Concrete, Class C		2.51	2.51	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1465066	601.002.013 Concrete, Class H		3.50	3.50	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1465067	601.002.014 Concrete, Class H Modified		3.50	3.50	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 09

Plant Name: SSC1.01.601 Superior Supply @ Caldwell, WV

Last Inspection: 06/07/2019

Sticker Expires: 12/7/2019

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1455077	601.002.003 Concrete, Class B	06/27/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1459815	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1459817	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1463269	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_1s)	(F_c+K_1s)- $X/1.4$ Increase
1463271	601.002.013 Concrete, Class H		3.47	3.47	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 06

Plant Name: SSC1.03.601 Smith Concrete F-3 @ Tiltonville OH

Last Inspection: 09/24/2019

Sticker Expires: 3/24/2020

Standard Deviation: 730.79

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1463265	601.002.022 Concrete, Class DC		3.73	3.73	6							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1463266	601.002.022 Concrete, Class DC		4.26	4.02	11	0	1.588	3.51	985.07	8622.73	> 3457.6	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1463293	601.002.004 Concrete, Class B Modified		3.95	3.95	9							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Greater than or equal to 2 inches

1463293	601.002.004 Concrete, Class B Modified		3.95	3.95	6							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Less than 2 inches

1463329	601.002.003 Concrete, Class B		2.87	2.87	8							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last One Year of Data Slump Greater than or equal to 2 inches

1463329	601.002.003 Concrete, Class B		2.87	2.63	65	3000	1.5	3	712.58	5755.85	> 5137.74	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1463331	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1463332	601.002.004 Concrete, Class B Modified		4.07	4.07	9							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1463337	601.002.006 Concrete, Class B Mass, Modified		3.45	3.45	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465022	601.002.011 Concrete, Class D		1.11	1.11	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901030	601.002.022 Concrete, Class DC		3.73	3.73	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 05

Plant Name: TBH1.01.601 Thomas, Bennet & Hunter, Inc @ Martinsburg, W

Last Inspection: 09/12/2019

Sticker Expires: 3/12/2020

Standard Deviation: 819.08

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Less than 2 inches												
389014 - R15	601.002.003		2.87	2.63	30	3000	1.501	3.008	871.79	5986.43	> 5622.34	= 0.24
	Concrete, Class B				DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Last Two Years of Data Slump Greater than or equal to 2 inches												
389014 - R15	601.002.003		2.87	2.63	91	3000	1.5	3	915.4	6160.55	> 5746.2	= 0.24
	Concrete, Class B				DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Last One Year of Data Slump Less than 2 inches												
389014 - R15	601.002.003		2.87	2.87	5							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last One Year of Data Slump Greater than or equal to 2 inches												
389014 - R15	601.002.003		2.87	2.87	9							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Last Three Months of Data Slump Greater than or equal to 2 inches												
389014 - R15	601.002.003		2.87	2.87	2							
	Concrete, Class B				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
389016 - R15	601.002.015	01/26/2018	3.37	3.37	1							
	Concrete, Class K				MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1389017 - R15	601.002.013 Concrete, Class H	01/27/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1398981	601.002.005 Concrete, Class B Mass		2.96	2.96	9							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Last One Year of Data Slump Greater than or equal to 2 inches												
1398981	601.002.005 Concrete, Class B Mass		2.96	2.72	43	3000	1.5	3	783.35	6029.51	> 5350.05	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1398981	601.002.005 Concrete, Class B Mass		2.96	2.72	18	3000	1.533	3.175	585.77	6327.22	> 4859.82	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1399059	601.002.004 Concrete, Class B Modified	10/01/2019	2.95	2.95	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 06

Plant Name: TSC1.01.601 Tri-Son Concrete Inc F-1 @ Bellaire, OH

Last Inspection: 04/05/2019

Sticker Expires: 10/5/2019

Standard Deviation: 869.53

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1455031	601.002.003 Concrete, Class B		2.87	2.87	8							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Three Months of Data Slump Less than 2 inches

1461843	601.002.015 Concrete, Class K		3.35	3.35	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Last Three Months of Data Slump Greater than or equal to 2 inches

1461843	601.002.015 Concrete, Class K		3.35	3.35	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Three Months of Data Slump Greater than or equal to 2 inches

1463285	601.002.013 Concrete, Class H		3.52	3.52	2							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 02 Plant Name: TWG1.01.601 The Wells Group F-1 @ South Williamson, KY
 Last Inspection: 10/22/2019 Sticker Expires: 4/22/2020 Standard Deviation: 650.00 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1394075	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421138	601.002.004 Concrete, Class B Modified	01/27/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455013	601.002.015 Concrete, Class K	06/13/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455022	601.002.013 Concrete, Class H	08/30/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459000	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461788	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 02

Plant Name: TWG1.02.601 The Wells Group F-2 @ Lovely, KY

Last Inspection: 10/22/2019

Sticker Expires: 4/22/2020

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
390295 RE-14	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421137	601.002.004 Concrete, Class B Modified	01/27/2018	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455014	601.002.015 Concrete, Class K	06/01/2018	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455023	601.002.013 Concrete, Class H	08/31/2018	3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459001	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461789	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 02

Plant Name: TWG1.03.601 The Wells Group F-3 @ Wayne, WV

Last Inspection: 05/10/2019

Sticker Expires: 11/10/2019

Standard Deviation: 650.00

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1420224	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421135	601.002.004 Concrete, Class B Modified	01/27/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455015	601.002.015 Concrete, Class K	06/02/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455024	601.002.013 Concrete, Class H	08/30/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458999	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461787	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 02

Plant Name: TWG1.04.601 The Wells Group F-4 @ Cannonsburg, KY

Last Inspection: 05/14/2019

Sticker Expires: 11/14/2019

Standard Deviation: 650.00

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Three Months of Data Slump Less than 2 inches

1420283	601.002.003 Concrete, Class B		2.87	2.87	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1455016	601.002.015 Concrete, Class K	06/01/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1455025	601.002.013 Concrete, Class H	08/30/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last One Year of Data Slump Greater than or equal to 2 inches

1459002	679.002.002 Concrete, Microsilica		3.83	3.83	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
1461790	601.002.022 Concrete, Class DC		3.74	3.74	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 02

Plant Name: TWG1.05.601 The Wells Group F-5 @ Louisa, KY

Last Inspection: 06/25/2019

Sticker Expires: 12/25/2019

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421064	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421104	601.002.013 Concrete, Class H	01/27/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421139	601.002.004 Concrete, Class B Modified	01/27/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455017	601.002.015 Concrete, Class K	06/01/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455026	601.002.013 Concrete, Class H	08/31/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459804	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461791	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 01

Plant Name: VBC1.03.601 Cardinal Concrete @ Robertsburg

Last Inspection: 08/19/2019

Sticker Expires: 2/19/2020

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Last Two Years of Data Slump Greater than or equal to 2 inches

1461856	601.002.003 Concrete, Class B		2.87	2.87	2							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1461857	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

District: 06 Plant Name: WIC1.01.601 Weirton Ice & Coal @ Weirton, WV
 Last Inspection: 04/04/2019 Sticker Expires: 10/4/2019 Standard Deviation: 854.39 Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455020	601.002.015 Concrete, Class K	08/05/2018	3.35	2.87	33	3000	1.5	3	1148.66	4722.99	< 6086.67	< 6445.98
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455021	601.002.003 Concrete, Class B	08/05/2018	2.87	2.87	33	3000	1.5	3	1148.66	4722.99	< 6086.67	< 6445.98
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455038	601.002.013 Concrete, Class H	10/21/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Last One Year of Data Slump Greater than or equal to 2 inches												
1461844	601.002.013 Concrete, Class H		3.50	3.50	3							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461858	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last Two Years of Data Slump Greater than or equal to 2 inches												
1463244	601.002.003 Concrete, Class B		2.87	2.87	20	3000	1.525	3.13	824.91	4257.99	< 4799	< 5581.97
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
Last One Year of Data Slump Greater than or equal to 2 inches												
1463244	601.002.003 Concrete, Class B		2.87	2.63	13	3000	1.565	3.365	463.82	5959.23	> 4560.75	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Last Three Months of Data Slump Greater than or equal to 2 inches												
1463244	601.002.003 Concrete, Class B		2.87	2.87	4							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463245	601.002.022 Concrete, Class DC		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 11/15/2019

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463263	601.002.022 Concrete, Class DC		3.73	3.73	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Last One Year of Data Slump Greater than or equal to 2 inches												
1463264	601.002.022 Concrete, Class DC		4.26	4.26	1							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463294	601.002.004 Concrete, Class B Modified		3.95	3.95	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463338	601.002.006 Concrete, Class B Mass, Modified		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												