



West Virginia Department of Transportation

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 07

Plant Name: ACX1.01.601 Central Supply F-8 @ Buckhannon

Last Inspection: 03/06/2020

Sticker Expires: 9/6/2020

Standard Deviation: 706.11

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434200	601.002.003 Concrete, Class B	03/05/2020	2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434200	601.002.003 Concrete, Class B	03/05/2020	2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434211	601.002.001 Concrete, Class A	03/28/2020	3.47	3.47	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434211	601.002.001 Concrete, Class A	03/28/2020	3.47	3.47	12	3500	1.576	3.429	1183.31	5364.9	< 6178.5	< 7557.57
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434213	601.002.003 Concrete, Class B	03/28/2020	2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434213	601.002.003 Concrete, Class B	03/28/2020	2.87	2.63	33	3000	1.5	3	722.34	5716.06	> 5167.02	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434217	601.002.015 Concrete, Class K	03/28/2020	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1434225	601.002.004 Concrete, Class B Modified		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434229	601.002.016 Concrete, Class K Modified		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434233	601.002.011 Concrete, Class D		2.04	2.04	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1436388	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1436444	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455043	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459838	601.002.003 Concrete, Class B		2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459842	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461801	679.002.002 Concrete, Microsilica		3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463308	601.002.001 Concrete, Class A	03/09/2019	3.49	3.49	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463317	601.002.015 Concrete, Class K	03/09/2019	3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463322	601.002.003 Concrete, Class B	03/09/2019	2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901027	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901397	601.002.011 Concrete, Class D		2.03	2.03	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901401	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901405	601.002.009 Concrete, Class C		2.51	2.51	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901409	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 02

Plant Name: ATA1.01.601 Adams Trucking And Supply @ Barboursville, W

Last Inspection: 02/27/2020

Sticker Expires: 8/27/2020

Standard Deviation: 577.97

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1424602	601.002.003 Concrete, Class B		2.87	2.87	10	3000	1.604	3.615	573.41	3919.75 <	5056 <	5072.88
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Data Slump Greater than or equal to 2 inches												
1424602	601.002.003 Concrete, Class B		2.87	2.87	10	3000	1.604	3.615	573.41	3919.75 <	5056 <	5072.88
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1424606	601.002.013 Concrete, Class H		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1424607	601.002.015 Concrete, Class K	03/20/2019	3.36	3.36	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1465018	601.002.015 Concrete, Class K		6.39	6.39	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1465018	601.002.015 Concrete, Class K		6.39	6.39	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1465064	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465065	601.002.003 Concrete, Class B		3.47	3.47	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000414	601.002.022 Concrete, Class DC		6.74	6.74	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 09

Plant Name: BMC1.01.601 Central Supply F-9 @ Summersville, WV

Last Inspection: 11/26/2019

Sticker Expires: 5/26/2020

Standard Deviation: 822.74

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1432574	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1432590	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1432590	601.002.003 Concrete, Class B		2.87	2.87	14	3000	1.557	3.313	639.5	3995.7	< 4819.29	< 5118.66
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434175	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1434175	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434222	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434222	601.002.003 Concrete, Class B		2.87	2.87	40	3000	1.5	3	809.07	4213.61 <	4578.5 <	5427.21
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436429	501.002.001 Concrete, Pavement		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1436465	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459809	601.002.001 Concrete, Class A		3.60	3.60	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461848	601.002.022 Concrete, Class DC		3.59	3.59	16	5166	1.543	3.233	1003.07	6713.74	< 6798.75	< 8408.93
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463336	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901015	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901018	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	(F_c+K_1s)	Average Strength(X)	(F_c+K_2s)
1901021	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	(F_c+K_1s)	Average Strength(X)	(F_c+K_2s)
1901024	601.002.001 Concrete, Class A		3.63	3.63	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 10

Plant Name: BMC1.03.601 Central Supply F-11 @ Princeton, WV

Last Inspection: 11/15/2019

Sticker Expires: 5/15/2020

Standard Deviation: 668.27

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1432575	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1432575	601.002.003 Concrete, Class B		2.87	2.63	19	3000	1.528	3.151	552.89	5098.68	> 4742.16	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1434168	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1434181	601.002.003 Concrete, Class B	11/07/2019	2.87	2.87	89	3000	1.5	3	658.18	3987.27	< 4292.44	< 4974.54
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1436467	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455001	601.002.013 Concrete, Class H	05/13/2018	3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1455005	601.002.022 Concrete, Class DC		3.61	3.61	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463301	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463344	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1901003	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901006	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901009	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901010	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901012	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 10

Plant Name: BMC1.04.601 Central Supply F-12 @ Bluefield, WV

Last Inspection: 11/15/2019

Sticker Expires: 5/15/2020

Standard Deviation: 473.57

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1432576	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1434169	601.002.015 Concrete, Class K	10/23/2019	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Less than 2 inches

1434182	601.002.003 Concrete, Class B	11/07/2019	2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

Data Slump Greater than or equal to 2 inches

1434182	601.002.003 Concrete, Class B	11/07/2019	2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436487	601.002.013 Concrete, Class H	05/13/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455006	601.002.022 Concrete, Class DC		3.61	3.61	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463302	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465013	601.002.013 Concrete, Class H		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901002	601.002.003 Concrete, Class B		2.85	2.85	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901005	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901008	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901011	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 09 Plant Name: BMC1.05.601 Central Supply F-13 @ Alta, WV

Last Inspection: 11/22/2019 Sticker Expires: 5/22/2020 Standard Deviation: 742.21 Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1432591	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1434176	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1434221	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1436466	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459801	679.002.002 Concrete, Microsilica		3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459810	601.002.002 Concrete, Class A Modified		3.60	3.60	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461849	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463335	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465019	601.002.004 Concrete, Class B Modified		3.12	2.88	23	3500	1.515	3.081	581.16	5300.43	> 5290.55	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901016	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901019	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901022	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K2s)</i>	<i>X-(Fc+K1s)/1.4</i>
1901025	601.002.001 Concrete, Class A		3.63	3.63	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 10

Plant Name: BMC1.06.601 Central Supply F-14 @ Beckley, WV

Last Inspection: 11/12/2019

Sticker Expires: 5/12/2020

Standard Deviation: 629.67

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1432573	601.002.003 Concrete, Class B		2.87	2.87	17	3000	1.538	3.202	925.18	4422.93	< 4801.76	< 5962.43
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												
Data Slump Greater than or equal to 2 inches												
1432573	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1432589	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434174	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434223	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1436464	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436486	601.002.013 Concrete, Class H	05/13/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1459808	601.002.001 Concrete, Class A		3.60	3.60	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459829	501.002.003 Concrete, Roller Compacted		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1459835	601.002.004 Concrete, Class B Modified	06/06/2019	3.24	3.24	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1459835	601.002.004 Concrete, Class B Modified	06/06/2019	3.24	3.24	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1461847	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1461847	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1463298	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1463298	601.002.003 Concrete, Class B		2.87	2.63	26	3000	1.508	3.044	495.15	5242.69	> 4507.24	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901014	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901017	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901020	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
1901023	601.002.001 Concrete, Class A		3.63	3.63	0							
						MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 03

Plant Name: CCC1.01.601 Cardinal Concrete F-1 @ Ravenswood, WV

Last Inspection: 10/22/2019

Sticker Expires: 4/22/2020

Standard Deviation: 681.67

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1398978	601.002.013 Concrete, Class H	12/29/2018	3.23	3.23	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1436396	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455072	601.002.022 Concrete, Class DC	06/21/2019	3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461784	679.002.002 Concrete, Microsilica		3.85	3.85	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461812	601.002.003 Concrete, Class B		2.87	2.63	34	3000	1.5	3	801.48	5867.94	> 5404.44	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Data Slump Greater than or equal to 2 inches												
1461812	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1461816	601.002.015 Concrete, Class K		3.36	3.36	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1461816	601.002.015 Concrete, Class K		3.36	3.36	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461820	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461854	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
2000416	601.002.013 Concrete, Class H		5.32	5.32	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
2000418	601.002.013 Concrete, Class H		6.48	6.48	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 03

Plant Name: CCC1.02.601 Cardinal Concrete F-2 @ Parkersburg, WV

Last Inspection: 09/24/2019

Sticker Expires: 3/24/2020

Standard Deviation: 862.62

Rating: B

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Data Slump Greater than or equal to 2 inches

1432578 601.002.003 2.92 2.92
Concrete, Class B

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Data Slump Greater than or equal to 2 inches

1432579 601.002.003 06/07/2019 2.89 2.89
Concrete, Class B

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1455049 601.002.015 02/11/2019 3.59 3.59
Concrete, Class K

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1459845 601.002.013 12/29/2018 3.45 3.45
Concrete, Class H

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461785	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461813	601.002.003 Concrete, Class B		2.87	2.87	42	3000	1.5	3	957.28	4435.92	< 5336.9	< 5871.84
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461817	601.002.015 Concrete, Class K		3.36	3.36	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461821	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 04

Plant Name: CCC1.03.601 Cardinal Concrete F-3 @ Bridgeport, WV

Last Inspection: 03/10/2020

Sticker Expires: 9/10/2020

Standard Deviation: 546.85

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1434187	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Less than 2 inches

1434188	601.002.015 Concrete, Class K	11/14/2019	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

Data Slump Greater than or equal to 2 inches

1434188	601.002.015 Concrete, Class K	11/14/2019	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1455051	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1455080	601.002.022 Concrete, Class DC	07/18/2019	3.74	3.74	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461786	679.002.002 Concrete, Microsilica		3.83	3.83	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461822	601.002.022 Concrete, Class DC		3.74	3.74	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1461855	601.002.022 Concrete, Class DC		3.74	3.74	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 04

Plant Name: CSC1.01.601 Central Supply F-1 @ Saltwell, WV

Last Inspection: 03/03/2020

Sticker Expires: 9/3/2020

Standard Deviation: 600.74

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1432544 601.002.013
Concrete, Class H

3.45 3.45

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1432553 679.002.002
Concrete, Microsilica

3.82 3.82

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1434196 601.002.003 **01/24/2020**
Concrete, Class B

2.87 2.87

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1434198 601.002.003 **01/24/2020**
Concrete, Class B

2.87 2.87

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434199	601.002.003 Concrete, Class B	03/28/2020	2.87	2.63	20	3000	1.525	3.13	378.76	5471.5	> 4185.52	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
1434199	601.002.003 Concrete, Class B	03/28/2020	2.87	2.87	42	3000	1.5	3	647.81	3971.72	< 4900	< 4943.43
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1436403	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436405	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1436419	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1455036	601.002.022 Concrete, Class DC		3.58	3.58	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1458960	601.002.016 Concrete, Class K Modified	02/06/2020	3.47	3.47	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463247	601.002.001 Concrete, Class A		3.47	3.47	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463248	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463249	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463250	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463251	601.002.013 Concrete, Class H		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463312	601.002.015 Concrete, Class K		3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463313	601.002.003 Concrete, Class B		2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901386	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901387	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 04

Plant Name: CSC1.02.601 Central Supply F-2 @ Westover, WV

Last Inspection: 03/02/2020

Sticker Expires: 9/2/2020

Standard Deviation: 693.62

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1432523	601.002.003 Concrete, Class B		2.87	2.63	26	3000	1.508	3.044	626.72	5649.62	> 4907.74	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Data Slump Greater than or equal to 2 inches												
1432523	601.002.003 Concrete, Class B		2.87	2.63	26	3000	1.508	3.044	626.72	5649.62	> 4907.74	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1432547	601.002.013 Concrete, Class H		3.45	3.45	13							
					MAINTAIN CURRENT CEMENT FACTOR, CONCRETE, CLASS H							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1432552	679.002.002 Concrete, Microsilica	05/09/2019	3.82	3.82	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1434192	601.002.003 Concrete, Class B	01/28/2020	2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434193	601.002.003 Concrete, Class B	01/24/2020	2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434193	601.002.003 Concrete, Class B	01/24/2020	2.87	2.87	40	3000	1.5	3	625.43	3938.14	< 4676.58	< 4876.29
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434195	601.002.001 Concrete, Class A	01/24/2020	3.47	3.47	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434195	601.002.001 Concrete, Class A	01/24/2020	3.47	3.47	23	3500	1.515	3.081	912.43	4882.33	< 5754.35	< 6311.2
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1436404	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1436404	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1436406	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1436406	601.002.015 Concrete, Class K		3.35	3.35	41	4000	1.5	3	686.52	5029.78	< 5870.39	< 6059.56
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455037	601.002.022 Concrete, Class DC		3.58	3.58	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458961	601.002.016 Concrete, Class K Modified	02/06/2020	3.47	3.47	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459833	501.002.003 Concrete, Roller Compacted		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463260	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463267	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463286	601.002.013 Concrete, Class H		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463287	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463288	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463310	601.002.015 Concrete, Class K		3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901391	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901395	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 08

Plant Name: CSC1.03.601 Central Supply F-3 @ Elkins, WV

Last Inspection: 03/04/2020

Sticker Expires: 9/4/2020

Standard Deviation: 656.54

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434201	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434201	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1434212	601.002.001 Concrete, Class A		3.47	3.47	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434214	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434214	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434218	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434218	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1434226	601.002.004 Concrete, Class B Modified		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434230	601.002.016 Concrete, Class K Modified		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434234	601.002.011 Concrete, Class D		2.04	2.04	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1436389	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1436389	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1436443	601.002.013 Concrete, Class H		3.45	3.45	29							
					MAINTAIN CURRENT CEMENT FACTOR, CONCRETE, CLASS H							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1455042	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1459834	601.002.004 Concrete, Class B Modified		3.37	3.37	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1459837	601.002.003 Concrete, Class B		2.86	2.86	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459841	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459844	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1461800	679.002.002 Concrete, Microsilica		3.82	3.82	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461824	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461826	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461828	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461830	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461832	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461845	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463305	601.002.001 Concrete, Class A	03/09/2019	3.49	3.49	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463314	601.002.015 Concrete, Class K	03/09/2019	3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463319	601.002.003 Concrete, Class B	03/09/2019	2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465016	601.002.004 Concrete, Class B Modified		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1901026	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901396	601.002.011 Concrete, Class D		2.03	2.03	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901400	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901404	601.002.009 Concrete, Class C		2.52	2.52	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901408	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 07

Plant Name: CSC1.04.601 Central Supply F-4 @ Gassaway, WV

Last Inspection: 03/05/2020

Sticker Expires: 9/5/2020

Standard Deviation: 563.21

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434202	601.002.003 Concrete, Class B	03/05/2020	2.87	2.63	10	3000	1.604	3.615	508.96	5052	> 4839.89	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434215	601.002.003 Concrete, Class B	03/28/2020	2.87	2.63	26	3000	1.508	3.044	709.02	5417.69	> 5158.26	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1434219	601.002.015 Concrete, Class K	03/28/2020	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434228	601.002.004 Concrete, Class B Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434232	601.002.016 Concrete, Class K Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1434235	601.002.011 Concrete, Class D		2.04	2.04	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436390	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436414	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1436446	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1455045	601.002.022 Concrete, Class DC		3.59	3.59	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1458980	679.002.002 Concrete, Microsilica		3.82	3.82	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459840	601.002.003 Concrete, Class B		2.86	2.86	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463307	601.002.001 Concrete, Class A	03/09/2019	3.49	3.49	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463316	601.002.015 Concrete, Class K	03/09/2019	3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463321	601.002.003 Concrete, Class B	03/09/2019	2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901028	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901398	601.002.011 Concrete, Class D		2.03	2.03	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901402	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901406	601.002.009 Concrete, Class C		2.51	2.51	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901410	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 07

Plant Name: CSC1.05.601 Central Supply F-5 @ Glenville, WV

Last Inspection: 03/05/2020

Sticker Expires: 9/5/2020

Standard Deviation: 530.94

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1434203	601.002.003 Concrete, Class B	03/05/2020	2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434203	601.002.003 Concrete, Class B	03/05/2020	2.87	2.87	16	3000	1.543	3.233	507.51	3783.09	< 4601.88	< 4640.78
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1434216	601.002.003 Concrete, Class B	02/01/2020	2.87	2.87	10	3000	1.604	3.615	908.1	4456.59	< 4758	< 6282.78
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1434220	601.002.015 Concrete, Class K	03/28/2020	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1434220	601.002.015 Concrete, Class K	03/28/2020	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434227	601.002.004 Concrete, Class B Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434231	601.002.016 Concrete, Class K Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1434236	601.002.011 Concrete, Class D		2.04	2.04	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1436391	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436415	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1436445	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1455044	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458979	679.002.002 Concrete, Microsilica		3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459839	601.002.003 Concrete, Class B		2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459843	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463306	601.002.001 Concrete, Class A	03/09/2019	3.49	3.49	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463315	601.002.015 Concrete, Class K	03/09/2019	3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463320	601.002.003 Concrete, Class B	03/09/2019	2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901029	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901399	601.002.011 Concrete, Class D		2.03	2.03	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901403	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901407	601.002.009 Concrete, Class C		2.51	2.51	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901411	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 03

Plant Name: CSC1.15.601 Central Supply F-15 @ Pennsboro, WV

Last Inspection: 03/03/2020

Sticker Expires: 9/3/2020

Standard Deviation: 604.91

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458974	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1458975	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1458975	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1458976	601.002.003 Concrete, Class B		2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1458976	601.002.003 Concrete, Class B		2.86	2.62	17	3000	1.538	3.202	700.85	5442.94	> 5244.12	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458977	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458978	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459812	679.002.002 Concrete, Microsilica		3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463246	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463309	601.002.001 Concrete, Class A	03/09/2019	3.49	3.49	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463318	601.002.015 Concrete, Class K	03/09/2019	3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463323	601.002.003 Concrete, Class B	03/09/2019	2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1464653	601.002.022 Concrete, Class DC	11/24/2018	3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 08

Plant Name: CSC1.16.601 Central Supply F-16 @ Parsons, WV

Last Inspection: 03/26/2020

Sticker Expires: 9/26/2020

Standard Deviation: 591.27

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461825	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461827	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461829	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461831	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461833	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461835	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1461836	601.002.003 Concrete, Class B		2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1461837	601.002.004 Concrete, Class B Modified		3.37	3.37	21	5300	1.521	3.112	570.48	6167.7	< 6172.38	< 7075.33
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461838	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461846	601.002.001 Concrete, Class A		3.47	3.47	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465015	601.002.004 Concrete, Class B Modified		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465021	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01

Plant Name: CSC2.01.601 Claxton Smith Concrete F-1 @ Poca, WV

Last Inspection: 03/12/2020

Sticker Expires: 9/12/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436474	501.002.001 Concrete, Pavement	04/21/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436477	501.002.001 Concrete, Pavement	04/20/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455053	601.002.022 Concrete, Class DC	03/13/2019	3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1461805	601.002.003 Concrete, Class B		2.95	2.95	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 02

Plant Name: CSC2.02.601 Claxton Smith Concrete F-2 @ Culloden, WV

Last Inspection: 10/25/2019

Sticker Expires: 4/25/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436472	501.002.001 Concrete, Pavement	04/21/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436475	501.002.002 Concrete, Pavement HES	04/20/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455054	601.002.022 Concrete, Class DC	03/13/2019	3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461804	601.002.003 Concrete, Class B		2.96	2.96	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01

Plant Name: CSC2.03.601 Claxton Smith Concrete F-3 @ Charleston, WV

Last Inspection: 09/11/2019

Sticker Expires: 3/11/2020

Standard Deviation: 661.33

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436473	501.002.001 Concrete, Pavement	04/21/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436476	501.002.002 Concrete, Pavement HES	04/20/2018	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455055	601.002.022 Concrete, Class DC	03/13/2019	3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1461803	601.002.003 Concrete, Class B		2.96	2.96	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1461803	601.002.003 Concrete, Class B		2.96	2.96	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

District: 06

Plant Name: DCC1.01.601 D.W. Dickey Concrete @ Steubenville, OH

Last Inspection: 03/04/2020

Sticker Expires: 9/4/2020

Standard Deviation: 650.00

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1399046	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1399046	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 05

Plant Name: DCX1.01.601 Dan Lee Co. F-1 @ Inwood, WV (Transit)

Last Inspection: 03/12/2020

Sticker Expires: 9/12/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1458943	601.002.003 Concrete, Class B	10/05/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

2000400	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

2000401	601.002.004 Concrete, Class B Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

2000402	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 10

Plant Name: DHC1.02.601 Central Supply @ Mabscott, WV

Last Inspection: 11/12/2019

Sticker Expires: 5/12/2020

Standard Deviation: 350.90

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458992	601.002.003 Concrete, Class B		2.87	2.63	14	3000	1.557	3.313	423.64	5302.86	> 4403.52	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1458993	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1459836	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1461802	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463296	601.002.003 Concrete, Class B	06/06/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1463299	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1463299	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1463300	601.002.015 Concrete, Class K	11/07/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465068	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 10 Plant Name: EC11.01.601 Eastern Concrete Pinville WV

Last Inspection: 10/15/2019 Sticker Expires: 4/15/2020 Standard Deviation: 842.54 Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1463324	601.002.003 Concrete, Class B		2.87	2.87	14	4300	1.557	3.313	664.32	5323.57	< 5334.35	= 0
					INCREASE CEMENT FACTOR BY 0 PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Data Slump Less than 2 inches												
1463325	501.002.001 Concrete, Pavement		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1463325	501.002.001 Concrete, Pavement		2.87	2.87	97	4300	1.5	3	782.59	4961.86	< 5473.88	= 0
					INCREASE CEMENT FACTOR BY 0 PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Data Slump Greater than or equal to 2 inches												
1463326	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Data Slump Greater than or equal to 2 inches												
1463327	601.002.022 Concrete, Class DC		3.74	3.74	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Data Slump Greater than or equal to 2 inches												
1463328	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Data Slump Greater than or equal to 2 inches												
1465023	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Data Slump Greater than or equal to 2 inches												
1465024	501.002.001 Concrete, Pavement		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01

Plant Name: ERM1.02.601 Hanson Ready Mix F-2 @ Gallipolis, OH

Last Inspection: 07/18/2019

Sticker Expires: 1/18/2020

Standard Deviation: 493.22

Rating: B

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1459802	601.002.013 Concrete, Class H	12/04/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459811	601.002.003 Concrete, Class B	03/11/2019	2.87	2.87	25	3000	1.511	3.055	506.93	3765.97	< 4450.8	< 4548.67
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1459827	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459831	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461797	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1461842	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465029	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465032	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465037	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465042	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465047	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465052	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>(Fc+K1s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K2s)</i>
1465061	601.002.022 Concrete, Class DC		3.72	3.72	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 06

Plant Name: ERM1.03.601 Hanson Ready Mix F-3 @ New Martinsville, WV

Last Inspection: 11/15/2019

Sticker Expires: 5/15/2020

Standard Deviation: 544.14

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1455087	601.002.013 Concrete, Class H	07/26/2019	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1455089	601.002.015 Concrete, Class K	08/01/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1458939	679.002.002 Concrete, Microsilica	08/22/2019	3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1461780	601.002.015 Concrete, Class K		3.41	3.41	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1461780	601.002.015 Concrete, Class K		3.41	3.41	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1461798	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1461798	601.002.003 Concrete, Class B		2.87	2.63	40	3000	1.5	3	478.53	5154.5	> 4435.59	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1461823	601.002.022 Concrete, Class DC		3.75	3.75	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1463259	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465083	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901032	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901034	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901036	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901038	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901040	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1901414	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
2000404	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
2000406	601.002.005 Concrete, Class B Mass		3.24	3.24	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
2000408	601.002.005 Concrete, Class B Mass		3.24	3.24	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
2000410	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X - (F_c+K_1s)/1.4$
2000424	601.002.004 Concrete, Class B Modified		7.05	7.05	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 06

Plant Name: ERM1.04.601 Hanson Ready Mix F-4 @ McMechen WV

Last Inspection: 11/15/2019

Sticker Expires: 5/15/2020

Standard Deviation: 684.43

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1461779	601.002.022 Concrete, Class DC		3.75	3.75	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Less than 2 inches

1461781	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Data Slump Greater than or equal to 2 inches

1461781	601.002.015 Concrete, Class K		3.35	3.35	14	4000	1.557	3.313	547.73	4852.82	< 5205	< 5814.63
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Data Slump Less than 2 inches

1461799	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Data Slump Greater than or equal to 2 inches

1461799	601.002.003 Concrete, Class B		2.87	2.63	36	3000	1.5	3	642.64	5070	> 4927.92	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1463258	601.002.013 Concrete, Class H		3.45	3.45	17							
					MAINTAIN CURRENT CEMENT FACTOR, CONCRETE, CLASS H							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465082	601.002.013 Concrete, Class H		3.45	3.45	17							
					MAINTAIN CURRENT CEMENT FACTOR, CONCRETE, CLASS H							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1901031	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901033	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901035	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901037	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901039	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901413	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000403	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000405	601.002.005 Concrete, Class B Mass		3.24	3.24	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000407	601.002.005 Concrete, Class B Mass		3.24	3.24	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000409	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000420	601.002.003 Concrete, Class B		0	0	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000423	601.002.004 Concrete, Class B Modified		7.05	7.05	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01

Plant Name: ERM1.05.601 Hanson Ready Mix F-5 @ Winfield, WV

Last Inspection: 02/24/2020

Sticker Expires: 8/24/2020

Standard Deviation: 585.02

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1424567	601.002.004 Concrete, Class B Modified	03/11/2019	3.34	3.34	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1424572	601.002.003 Concrete, Class B	03/11/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1424599	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1436421	601.002.003 Concrete, Class B		2.87	2.63	17	3000	1.538	3.202	589.46	5515.29	> 4887.45	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Data Slump Greater than or equal to 2 inches												
1436421	601.002.003 Concrete, Class B		2.87	2.63	17	3000	1.538	3.202	589.46	5515.29	> 4887.45	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436426	601.002.022 Concrete, Class DC		3.73	3.73	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455029	601.002.014 Concrete, Class H Modified	09/03/2018	3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458948	601.002.015 Concrete, Class K	03/08/2020	3.83	3.83	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1459006	601.002.015 Concrete, Class K		3.39	3.39	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1459006	601.002.015 Concrete, Class K		3.39	3.39	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1459828	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459832	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1461792	601.002.003 Concrete, Class B		2.87	2.63	13	3000	1.565	3.365	661.78	5513.85	> 5226.89	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Data Slump Greater than or equal to 2 inches												
1461792	601.002.003 Concrete, Class B		2.87	2.63	13	3000	1.565	3.365	661.78	5513.85	> 5226.89	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461794	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1461839	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1461839	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465027	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465030	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465034	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465039	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1465044	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1465044	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1465049	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1465049	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465058	601.002.022 Concrete, Class DC		3.72	3.72	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 03

Plant Name: ERM1.06.601 Hanson Ready Mix F-6 @ Parkersburg, WV

Last Inspection: 02/24/2020

Sticker Expires: 8/24/2020

Standard Deviation: 563.40

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1436399	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1436399	601.002.003 Concrete, Class B		2.87	2.87	10	3000	1.604	3.615	550.11	3882.38	< 4342	< 4988.65
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455027	601.002.023 Concrete, Class H-IC	09/07/2018	3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455050	601.002.022 Concrete, Class DC	02/21/2019	3.73	3.73	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1455090	601.002.013 Concrete, Class H	08/02/2019	3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461834	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463257	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463304	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1465020	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1465053	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1465053	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1465054	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465055	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1465056	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1465056	601.002.003 Concrete, Class B		2.87	2.87	52	3000	1.5	3	502.93	3754.4	< 4386.15	< 4508.79
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465072	601.002.003 Concrete, Class B		2.87	2.63	31	3000	1.5	3	687.18	5153.87	> 5061.54	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01

Plant Name: ERM1.07.601 Hanson Ready Mix F-7 @ Charleston, WV

Last Inspection: 02/25/2020

Sticker Expires: 8/25/2020

Standard Deviation: 541.02

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Data Slump Greater than or equal to 2 inches

1424571	601.002.003 Concrete, Class B	03/11/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1424600	601.002.013 Concrete, Class H	02/13/2019	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1432540	679.002.002 Concrete, Microsilica		3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Data Slump Greater than or equal to 2 inches

1436420	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436453	601.002.022 Concrete, Class DC		3.73	3.73	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436478	601.002.016 Concrete, Class K Modified	04/20/2018	4.07	4.07	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436479	601.002.015 Concrete, Class K	04/21/2018	4.07	4.07	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436480	601.002.003 Concrete, Class B		4.07	4.07	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436481	601.002.003 Concrete, Class B		4.07	4.07	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455088	679.002.002 Concrete, Microsilica	07/27/2019	3.82	3.82	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458950	601.002.015 Concrete, Class K	03/08/2020	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1459008	601.002.015 Concrete, Class K		3.39	3.39	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1459826	601.002.013 Concrete, Class H		3.45	3.45	22							
					MAINTAIN CURRENT CEMENT FACTOR, CONCRETE, CLASS H							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1459830	601.002.013 Concrete, Class H		3.45	3.45	13							
					MAINTAIN CURRENT CEMENT FACTOR, CONCRETE, CLASS H							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461796	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461841	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465025	601.002.013 Concrete, Class H		3.45	3.45	27							
MAINTAIN CURRENT CEMENT FACTOR, CONCRETE, CLASS H												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465026	601.002.013 Concrete, Class H		3.45	3.45	14							
MAINTAIN CURRENT CEMENT FACTOR, CONCRETE, CLASS H												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465033	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465038	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465043	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465048	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465057	601.002.022 Concrete, Class DC		3.72	3.72	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 02

Plant Name: ERM1.08.601 Hanson Ready Mix F-8 @ Huntington, WV

Last Inspection: 11/11/2019

Sticker Expires: 5/11/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458946	601.002.013 Concrete, Class H	12/04/2019	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458947	601.002.015 Concrete, Class K	03/08/2020	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1459005	601.002.015 Concrete, Class K		3.39	3.39	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1463334	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465028	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465031	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465036	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465041	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465046	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465051	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465060	601.002.022 Concrete, Class DC		3.72	3.72	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01

Plant Name: ERM1.09.601 Hanson Ready Mix F-9 @ Winfield, WV (Transit)

Last Inspection: 02/24/2020

Sticker Expires: 8/24/2020

Standard Deviation: 414.20

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458949	601.002.015 Concrete, Class K	03/08/2020	3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1459007	601.002.015 Concrete, Class K		3.39	3.39	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461793	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461795	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461840	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465035	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1465040	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465045	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
1465050	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
1465059	601.002.022 Concrete, Class DC		3.72	3.72	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 05

Plant Name: FCC1.01.601 Fairfax Concrete F-1 @ Scherr WV

Last Inspection: 03/12/2020

Sticker Expires: 9/12/2020

Standard Deviation: 738.68

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421095	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421097	601.002.004 Concrete, Class B Modified	06/20/2019	3.33	3.33	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1421098	601.002.003 Concrete, Class B	08/21/2019	2.86	2.62	14	3000	1.557	3.313	702.56	6633.64	> 5327.58	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1421100	601.002.015 Concrete, Class K		3.33	3.33	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1421102	601.002.013 Concrete, Class H		3.44	3.44	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1432581	601.002.003 Concrete, Class B	06/07/2019	2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455035	601.002.023 Concrete, Class H-IC	10/14/2018	3.46	3.46	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455046	601.002.023 Concrete, Class H-IC	01/27/2019	3.43	3.43	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455076	601.002.003 Concrete, Class B	07/17/2019	2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458971	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463272	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1463275	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1463275	601.002.003 Concrete, Class B		2.87	2.87	38	4356	1.5	3	701.43	5408.14	< 6445.47	< 6460.29
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463278	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463281	601.002.013 Concrete, Class H		3.44	3.44	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000411	601.002.004 Concrete, Class B Modified		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 08

Plant Name: FCC1.02.601 Fairfax Concrete F-2 @ Oakland, MD

Last Inspection: 03/18/2020

Sticker Expires: 9/18/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1424543	601.002.015 Concrete, Class K		3.33	3.33	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1424584	601.002.003 Concrete, Class B	03/11/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1432582	601.002.003 Concrete, Class B	08/23/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455034	601.002.023 Concrete, Class H-IC	10/14/2018	3.46	3.46	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455048	601.002.023 Concrete, Class H-IC	01/27/2019	3.43	3.43	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455075	601.002.003 Concrete, Class B	07/17/2019	2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1458973	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463274	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463277	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463280	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463283	601.002.013 Concrete, Class H		3.44	3.44	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000413	601.002.004 Concrete, Class B Modified		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 08

Plant Name: FCC1.04.601 Fairfax Concrete F-4 @ Thomas WV

Last Inspection: 09/10/2019

Sticker Expires: 3/10/2020

Standard Deviation: 670.47

Rating: B

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1424542	601.002.015 Concrete, Class K		3.33	3.33	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1424583	601.002.013 Concrete, Class H		3.44	3.44	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1432580	601.002.003 Concrete, Class B	06/07/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455033	601.002.023 Concrete, Class H-IC	10/14/2018	3.46	3.46	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455047	601.002.023 Concrete, Class H-IC	01/27/2019	3.43	3.43	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455074	601.002.003 Concrete, Class B	07/17/2019	2.86	2.86	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458972	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463273	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463276	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463279	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463282	601.002.013 Concrete, Class H		3.44	3.44	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000412	601.002.004 Concrete, Class B Modified		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 05

Plant Name: FCC1.05.601 Allegany Concrete F-5 W Short Gap WV (Transit)

Last Inspection: 03/09/2020

Sticker Expires: 9/9/2020

Standard Deviation: 337.93

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1436470	601.002.023 Concrete, Class H-IC	04/02/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455028	601.002.023 Concrete, Class H-IC	09/07/2018	3.46	3.46	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1461806	601.002.004 Concrete, Class B Modified		3.34	3.34	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1461807	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1461807	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1461808	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1461808	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463284	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 09

Plant Name: GRM1.01.601 Greenbrier Ready Mix, Caldwell WV

Last Inspection: 11/27/2019

Sticker Expires: 5/27/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1459803 601.002.003
Concrete, Class B

2.87 2.87

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1459814 601.002.015
Concrete, Class K

3.35 3.35

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1459816 601.002.003
Concrete, Class B

2.87 2.87

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1463268 601.002.022
Concrete, Class DC

3.59 3.59

0

MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
---	--	--	--	--	--	--	--	--	--	--	--	--

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>(Fc+K1s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K2s)</i>
1463270	601.002.013 Concrete, Class H		3.47	3.47	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 10

Plant Name: JRM1.01.601 Jowar Ready Mix @ laeger, WV

Last Inspection: 03/16/2020

Sticker Expires: 9/16/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455052	601.002.003 Concrete, Class B	02/28/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463261	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463262	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463339	601.002.003 Concrete, Class B		3.23	3.23	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463340	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463341	601.002.003 Concrete, Class B		3.23	3.23	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463342	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 10

Plant Name: KCX1.03.601 Kokosing Construction Company F-3 @ Sophia,

Last Inspection: 03/10/2020

Sticker Expires: 9/10/2020

Standard Deviation: 597.91

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1463343	501.002.001 Concrete, Pavement		2.87	2.63	84	3000	1.5	3	650.47	5247.14	> 4951.41	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Data Slump Greater than or equal to 2 inches												
1463343	501.002.001 Concrete, Pavement		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465017	501.002.001 Concrete, Pavement		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465062	501.002.001 Concrete, Pavement		2.87	2.63	148	3000	1.5	3	567.21	5441.89	> 4701.63	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
1465062	501.002.001 Concrete, Pavement		2.87	2.63	20	3000	1.525	3.13	603.86	5534	> 4890.08	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K2s)</i>	<i>X-(Fc+K1s)/1.4</i>
1465063	501.002.001 Concrete, Pavement		2.88	2.88	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 02

Plant Name: LCC1.01.601 Logan Concrete F-1 @ Logan, WV

Last Inspection: 02/26/2020

Sticker Expires: 8/26/2020

Standard Deviation: 508.31

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Data Slump Greater than or equal to 2 inches

1455065	601.002.003 Concrete, Class B	03/22/2019	2.89	2.89	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1455066	601.002.015 Concrete, Class K	03/21/2019	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1455067	601.002.022 Concrete, Class DC	03/22/2019	3.74	3.74	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

1455068	601.002.013 Concrete, Class H	03/21/2019	3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461782	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1461810	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1461814	601.002.015 Concrete, Class K		3.36	3.36	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1461814	601.002.015 Concrete, Class K		3.36	3.36	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1461818	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
Data Slump Greater than or equal to 2 inches												
1461850	501.002.001 Concrete, Pavement		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X-(F_c+K_1s)/1.4$
Data Slump Greater than or equal to 2 inches												
1461852	601.002.013 Concrete, Class H		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01

Plant Name: MRM2.01.601 Logan Concrete, Inc. - Madison Plant @ Madison,

Last Inspection: 10/23/2019

Sticker Expires: 4/23/2020

Standard Deviation: 564.97

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436409	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436410	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436482	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1436483	601.002.004 Concrete, Class B Modified	05/06/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455030	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461783	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1461811	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1461815	601.002.015 Concrete, Class K		3.36	3.36	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1461815	601.002.015 Concrete, Class K		3.36	3.36	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461819	601.002.022 Concrete, Class DC		3.74	3.74	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1461851	501.002.001 Concrete, Pavement		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1461853	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01

Plant Name: MRM3.01.601 Mozack Ready Mix, Winfield WV

Last Inspection: 09/30/2019

Sticker Expires: 3/30/2020

Standard Deviation: 499.28

Rating: B

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1458937	601.002.003 Concrete, Class B	08/21/2019	2.87	2.87	47	3000	1.5	3	509.9	3764.85	< 4268.51	< 4529.7
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							
Data Slump Greater than or equal to 2 inches												
1458937	601.002.003 Concrete, Class B	08/21/2019	2.87	2.87	47	3000	1.5	3	509.9	3764.85	< 4268.51	< 4529.7
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458938	601.002.015 Concrete, Class K	08/21/2019	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1458994	601.002.003 Concrete, Class B		4.07	4.07	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459003	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459004	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459824	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

-----<----- Evaluation of Cement Requirements ----->-----

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459825	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463252	601.002.015 Concrete, Class K		3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463253	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463254	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463255	601.002.003 Concrete, Class B		2.89	2.89	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463256	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465069	601.002.003 Concrete, Class B		2.88	2.88	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465070	601.002.015 Concrete, Class K		3.37	3.37	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1465071	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1901001	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

District: 09 Plant Name: PCI1.01.601 Pro Contracting INC

Last Inspection: 08/08/2019 Sticker Expires: 2/8/2020 Standard Deviation: 650.00 Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463295	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01

Plant Name: RRM1.01.601 Rumble Ready Mix F-1 @ Winfield, WV

Last Inspection: 11/12/2019

Sticker Expires: 5/12/2020

Standard Deviation: 589.91

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1455041	601.002.016 Concrete, Class K Modified	08/07/2019	3.35	3.11	12	3000	1.576	3.429	117.33	8587.5	> 3402.32	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1455099	501.002.002 Concrete, Pavement HES	08/07/2019	3.35	3.11	12	3000	1.576	3.429	117.33	8587.5	> 3402.32	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1458929	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1458929	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458931	601.002.022 Concrete, Class DC	08/15/2019	3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458933	601.002.015 Concrete, Class K	08/15/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458935	601.002.013 Concrete, Class H	08/17/2019	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Less than 2 inches												
1458962	601.002.003 Concrete, Class B	02/08/2020	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1458962	601.002.003 Concrete, Class B	02/08/2020	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458964	601.002.022 Concrete, Class DC	02/08/2020	3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458966	601.002.024 Concrete, Class B w/ Fly Ash	02/08/2020	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458968	601.002.015 Concrete, Class K	02/08/2020	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458982	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458984	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458988	501.002.002 Concrete, Pavement HES		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458990	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01

Plant Name: RRM1.02.601 Rumble Ready Mix F-2 @ Belle, WV

Last Inspection: 10/05/2018

Sticker Expires: 4/5/2019

Standard Deviation: 650.00

Rating: B

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1455100	501.002.002 Concrete, Pavement HES	08/08/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458930	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458932	601.002.022 Concrete, Class DC	08/15/2019	3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458934	601.002.015 Concrete, Class K	08/15/2019	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458936	601.002.013 Concrete, Class H	08/18/2019	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458963	601.002.003 Concrete, Class B	02/08/2020	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458965	601.002.022 Concrete, Class DC	02/08/2020	3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458967	601.002.024 Concrete, Class B w/ Fly Ash	02/08/2020	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458969	601.002.015 Concrete, Class K	02/08/2020	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458983	601.002.013 Concrete, Class H		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458985	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458989	501.002.002 Concrete, Pavement HES		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1458991	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

District: 03 Plant Name: SCC1.01.601 Smith Concrete F-1 @ Porterfield, OH

Last Inspection: 10/08/2019 Sticker Expires: 4/8/2020 Standard Deviation: 719.54 Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1455069	601.002.003 Concrete, Class B	04/03/2019	2.89	2.89	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1463289	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												
Data Slump Greater than or equal to 2 inches												
1463289	601.002.003 Concrete, Class B		2.87	2.87	19	3861	1.528	3.151	706.21	4940.09	< 5040.53	< 6086.27
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 03

Plant Name: SCC1.02.601 Smith Concrete F-2 @ Reno, OH

Last Inspection: 02/26/2020

Sticker Expires: 8/26/2020

Standard Deviation: 665.84

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455070	601.002.003 Concrete, Class B	04/03/2019	2.91	2.91	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463290	601.002.003 Concrete, Class B		2.87	2.87	24	4300	1.513	3.067	445.01	4973.3	< 5241.25	< 5664.85
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1463330	601.002.022 Concrete, Class DC		3.73	4.73	16	5800	1.543	3.233	992.24	6438.75	< 7331.03	= 1
INCREASE CEMENT FACTOR BY 1 PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1463333	601.002.009 Concrete, Class C		2.51	2.51	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Data Slump Greater than or equal to 2 inches												
1465066	601.002.013 Concrete, Class H		3.50	3.50	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
Data Slump Greater than or equal to 2 inches												
1465067	601.002.014 Concrete, Class H Modified		3.50	3.50	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 09

Plant Name: SSC1.01.601 Superior Supply @ Caldwell, WV

Last Inspection: 11/27/2019

Sticker Expires: 5/27/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1455077	601.002.003 Concrete, Class B	06/27/2019	2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1459815	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1459817	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
1463269	601.002.022 Concrete, Class DC		3.59	3.59	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K1s)</i>	<i>(Fc+K1s)-X/1.4 Increase</i>
1463271	601.002.013 Concrete, Class H		3.47	3.47	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 06

Plant Name: SSC1.03.601 Smith Concrete F-3 @ Tiltonsville OH

Last Inspection: 09/24/2019

Sticker Expires: 3/24/2020

Standard Deviation: 621.20

Rating: B

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	-------------------------

Data Slump Greater than or equal to 2 inches

1463265	601.002.022 Concrete, Class DC		3.73	3.73	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	-------------------------

Data Slump Greater than or equal to 2 inches

1463266	601.002.022 Concrete, Class DC		4.26	4.26	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K1s)	(Fc+K1s)-X/1.4 Increase
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	-------------------------

Data Slump Greater than or equal to 2 inches

1463293	601.002.004 Concrete, Class B Modified		3.95	3.95	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1463329	601.002.003 Concrete, Class B		2.87	2.63	63	3000	1.5	3	704.32	5758.25	> 5112.96	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							
Data Slump Greater than or equal to 2 inches												
1463329	601.002.003 Concrete, Class B		2.87	2.63	63	3000	1.5	3	704.32	5758.25	> 5112.96	= 0.24
					DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1463331	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1463332	601.002.004 Concrete, Class B Modified		4.07	4.07	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1463337	601.002.006 Concrete, Class B Mass, Modified		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1465022	601.002.011 Concrete, Class D		1.11	1.11	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1901030	601.002.022 Concrete, Class DC		3.73	3.73	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1901412	601.002.006 Concrete, Class B Mass, Modified		3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

District: 06 Plant Name: SWC1.01.601 Swank @ Tridelphia, WV

Last Inspection: 01/30/2020 Sticker Expires: 7/30/2020 Standard Deviation: 650.00 Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
2000425	601.002.004 Concrete, Class B Modified		7.05	7.05	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 05

Plant Name: TBH1.01.601 Thomas, Bennet & Hunter, Inc @ Martinsburg, W

Last Inspection: 03/12/2020

Sticker Expires: 9/12/2020

Standard Deviation: 704.12

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
I389014 - R15	601.002.003 Concrete, Class B		2.87	2.63	29	3000	1.503	3.016	661.73	5619.24	> 4995.78	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												
Data Slump Greater than or equal to 2 inches												
I389014 - R15	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1398981	601.002.005 Concrete, Class B Mass	01/24/2020	2.96	2.72	76	3000	1.5	3	682.31	6101.59	> 5046.93	= 0.24
DECREASE CEMENT FACTOR BY 0.24 PER SECTION 3.3 OF MP 711.03.26												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
1399059	601.002.004 Concrete, Class B Modified	10/01/2019	2.95	2.95	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(F_c)	Factor (K_1)	Factor (K_2)	Standard Deviation (s)	Average Strength(X)	(F_c+K_2s)	$X - (F_c+K_1s)/1.4$
2000432	601.002.003 Concrete, Class B		5.63	5.63	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 06

Plant Name: TSC1.01.601 Tri-Son Concrete Inc F-1 @ Bellaire, OH

Last Inspection: 11/01/2019

Sticker Expires: 5/1/2020

Standard Deviation: 869.53

Rating: A-1

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Data Slump Greater than or equal to 2 inches

1455031	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Data Slump Less than 2 inches

1461843	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

Data Slump Greater than or equal to 2 inches

1461843	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	---------------------	----------	----------------

Data Slump Greater than or equal to 2 inches

1463285	601.002.013 Concrete, Class H		3.52	3.52	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 02

Plant Name: TWG1.01.601 The Wells Group F-1 @ South Williamson, KY

Last Inspection: 10/22/2019

Sticker Expires: 4/22/2020

Standard Deviation: 589.55

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	Average Strength(X)	(Fc+K2s)	X-(Fc+K1s)/1.4
Data Slump Greater than or equal to 2 inches												
1394075	601.002.003 Concrete, Class B		2.87	2.87	13	3000	1.565	3.365	589.55	3922.65	< 4973.08	< 4983.84
					MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455013	601.002.015 Concrete, Class K	06/13/2018	3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455022	601.002.013 Concrete, Class H	08/30/2018	3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459000	679.002.002 Concrete, Microsilica		3.83	3.83	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>(Fc+K1s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K2s)</i>
1461788	601.002.022 Concrete, Class DC		3.74	3.74	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 02

Plant Name: TWG1.02.601 The Wells Group F-2 @ Lovely, KY

Last Inspection: 10/22/2019

Sticker Expires: 4/22/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
390295 RE-14	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455014	601.002.015 Concrete, Class K	06/01/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455023	601.002.013 Concrete, Class H	08/31/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459001	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>(Fc+K1s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K2s)</i>
1461789	601.002.022 Concrete, Class DC		3.74	3.74	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 02

Plant Name: TWG1.03.601 The Wells Group F-3 @ Wayne, WV

Last Inspection: 11/15/2019

Sticker Expires: 5/15/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1420224	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455015	601.002.015 Concrete, Class K	06/02/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455024	601.002.013 Concrete, Class H	08/30/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1458999	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>(Fc+K1s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K2s)</i>
1461787	601.002.022 Concrete, Class DC		3.74	3.74	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 02

Plant Name: TWG1.04.601 The Wells Group F-4 @ Cannonsburg, KY

Last Inspection: 11/14/2019

Sticker Expires: 5/14/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Less than 2 inches

1420283	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1455016	601.002.015 Concrete, Class K	06/01/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

1455025	601.002.013 Concrete, Class H	08/30/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
-------------------	------------------------------	--------------	------------------------	------------------------	----------------	---------------------	-------------	-------------	------------------------	----------	---------------------	----------

Data Slump Greater than or equal to 2 inches

1459002	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>(Fc+K1s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K2s)</i>
1461790	601.002.022 Concrete, Class DC		3.74	3.74	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 02

Plant Name: TWG1.05.601 The Wells Group F-5 @ Louisa, KY

Last Inspection: 12/26/2019

Sticker Expires: 6/26/2020

Standard Deviation: 650.00

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1421064	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455017	601.002.015 Concrete, Class K	06/01/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455026	601.002.013 Concrete, Class H	08/31/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1459804	679.002.002 Concrete, Microsilica		3.83	3.83	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>(Fc+K1s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K2s)</i>
1461791	601.002.022 Concrete, Class DC		3.74	3.74	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 01 Plant Name: VBC1.03.601 Cardinal Concrete @ Robertsburg

Last Inspection: 02/13/2020 Sticker Expires: 8/13/2020 Standard Deviation: 709.76 Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461856	601.002.003 Concrete, Class B		2.87	2.87	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1461857	601.002.015 Concrete, Class K		3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000415	601.002.013 Concrete, Class H		5.32	5.32	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
2000417	601.002.013 Concrete, Class H		6.48	6.48	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

<i>Mix Design Number</i>	<i>Material Code / Class of Mix</i>	<i>Expired Date</i>	<i>Approved Cement Factor</i>	<i>Adjusted Cement Factor</i>	<i>Pieces of Data</i>	<i>Design Strength(Fc</i>	<i>Factor (K1)</i>	<i>Factor (K2)</i>	<i>Standard Deviation (s)</i>	<i>(Fc+K1s)</i>	<i>Average Strength(X)</i>	<i>(Fc+K2s)</i>
2000419	601.002.022 Concrete, Class DC		3.74	3.74	0	MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA						

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

District: 06

Plant Name: WIC1.01.601 Weirton Ice & Coal @ Weirton, WV

Last Inspection: 10/04/2019

Sticker Expires: 4/4/2020

Standard Deviation: 824.48

Rating: A-1

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455020	601.002.015 Concrete, Class K	08/05/2018	3.35	3.35	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455021	601.002.003 Concrete, Class B	08/05/2018	2.87	2.87	33	3000	1.5	3	1148.66	4722.99	< 6086.67	< 6445.98
MAINTAIN CURRENT CEMENT FACTOR, PER SECTION 3.3 OF MP 711.03.26												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1455038	601.002.013 Concrete, Class H	10/21/2018	3.45	3.45	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1461844	601.002.013 Concrete, Class H		3.50	3.50	0							
MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA												

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Less than 2 inches												
1461858	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							
Data Slump Greater than or equal to 2 inches												
1461858	601.002.015 Concrete, Class K		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463244	601.002.003 Concrete, Class B		2.87	2.87	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463245	601.002.022 Concrete, Class DC		3.35	3.35	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
1463263	601.002.022 Concrete, Class DC		3.73	3.73	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

PCC Plant Evaluation with Cement Factors

Effective Date: 4/2/2020

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463264	601.002.022 Concrete, Class DC		4.26	4.26	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463294	601.002.004 Concrete, Class B Modified		3.95	3.95	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							

<----- Evaluation of Cement Requirements ----->

Mix Design Number	Material Code / Class of Mix	Expired Date	Approved Cement Factor	Adjusted Cement Factor	Pieces of Data	Design Strength(Fc)	Factor (K1)	Factor (K2)	Standard Deviation (s)	(Fc+K1s)	Average Strength(X)	(Fc+K2s)
Data Slump Greater than or equal to 2 inches												
1463338	601.002.006 Concrete, Class B Mass, Modified		3.45	3.45	0							
					MAINTAIN CURRENT CEMENT FACTOR, INSUFFICIENT AMOUNT OF DATA							